

Aria electronic multiprocessor controller



Installation and user manual

→ **LEGGI E CONSERVA
QUESTE ISTRUZIONI** ←
**READ AND SAVE
THESE INSTRUCTIONS**

CAREL
Technology & Evolution

**LEGGI E CONSERVA
QUESTE ISTRUZIONI** ←
**READ AND SAVE
THESE INSTRUCTIONS**

We wish to save you time and money!

We can assure you that a thorough reading of this manual will guarantee correct installation and safe use of the product described.

Contents

Introduction	4
1. GENERAL CHARACTERISTICS	4
1.1 Functions.....	4
1.2 Terminal.....	4
1.3 Power board for the control of stand alone air-conditioning units (code TABASE5000).....	5
1.4 Power board for the control of a motorized damper (multi-zone system codeTAZONE0000).....	6
1.5 Codes.....	6
2. APPLICATIONS	7
2.1 Stand-alone applications.....	7
2.1.1 Heating only.....	7
2.1.2 Cooling only.....	7
2.1.3 Conventional.....	8
2.1.4 Heat pump.....	8
2.1.5 Split system.....	8
2.2 Multi-zone control.....	8
2.3 Display terminal.....	8
2.4 Pool environments.....	8
2.5 Heat pump + Energy Saving.....	8
2.6 Split cooling only.....	8
3. INSTALLATION	9
3.1 Terminal installation.....	9
3.2 Connection diagrams for stand-alone applications.....	10
3.3 Installation of the relay power board (STAND ALONE system) and multi-zone power board.....	10
3.4 Connection diagrams for zone control applications.....	11
4. USER INTERFACE	12
4.1 Meaning of the symbols on the display.....	12
4.2 Description of the button meaning.....	12
4.2.1 Front and Side buttons.....	12
4.2.2 Programming.....	13
4.2.2.1 F Button [^] and Button [v].....	13
4.2.3 Selecting the machine's operating mode ([MODE] button).....	13
4.2.3.1 Selects the supply fan operating mode ([FAN] button, stand-alone version only).....	13
4.2.4 Setting the temperature and humidity set points.....	14
4.2.4.1 Setting the temperature set point category ([SET] button).....	14
4.2.4.2 Setting the humidity set point ([SET] button for 3 seconds).....	14
4.2.5 Programming the parameters.....	14
4.2.5.1 Setting the DIRECT parameters ([SET]+[HOLD] buttons).....	15
4.2.5.2 Setting the USER parameters (installer, [SET]+[MODE] buttons).....	15
4.2.5.3 Setting the FACTORY parameters (configuration, [SET]+[MODE] buttons for more than 3 seconds).....	15
4.2.5.4 Setting the default parameters ([SET] + [RESUME] buttons when powering the controller).....	15
4.2.6 Using the Hardware key.....	16
4.2.6.1 Copying parameters from the removable hardware key to the controller ([SET]+[^] buttons when powering Aria or even only [^] button when powering Aria).....	16
4.2.6.2 Copying parameters from the controller to the removable hardware key ([SET]+[v] buttons when powering Aria).....	16
4.2.7 Real time clock and time-bands.....	16
4.2.7.1 Setting the time ([CLOCK] button, version with built-in clock only).....	16
4.2.7.2 Time bands.....	16
4.2.7.3. Setting the time bands ([CLOCK] button more than 3 seconds).....	16
4.2.8 Alarm management and general functions.....	17
4.2.8.1 [HOLD] button.....	17
4.2.8.2 [RESUME] button.....	17
4.2.8.3 [RESUME] button for more than 3 seconds.....	17
4.2.8.4 [^] + [v] buttons simultaneously.....	17
5. OPERATION	18
5.1 General.....	18
5.2 Stand-alone version.....	18
5.2.1 Proportional regulation algorithm.....	18
5.2.2 Proportional + Integral regulation algorithm.....	20
5.2.3 Split operation.....	20
5.2.4 Defrost management.....	21
5.2.4.1 Forced defrost due to low outside temperature.....	21
5.2.4.2 Manual defrost.....	21
5.2.4.3 Compressor stops at start and end defrost.....	21
5.2.4.4 Supply fan activation delay after defrost.....	21
5.2.4.5 Smart defrost cycles.....	21
5.2.5 Dehumidification management.....	22
5.2.5.1 Dehumidification in Night-time or Unoccupied mode.....	22
5.2.5.2 Dehumidification stop temperature.....	22

5.2.6	Automatic set point compensation	23
5.2.7	Free-cooling & Free-heating	23
5.2.8	Using probes B2 and B3.....	24
5.2.9	Output management.....	25
5.3	Zone control version.....	27
5.3.1	Regulation algorithm.....	27
5.3.2	Damper management	28
5.4	Pool environment management	28
5.5	pLAN connection	29
5.5.1	List of variables.....	29
5.6	Digital inputs.....	33
5.7	Supervisor	33
6.	ALARMS AND TROUBLESHOOTING	37
6.1	Resetting the alarms.	37
6.1.1	Muting the buzzer:	37
6.1.2	Automatic reset:	37
6.1.3	Manual reset:.....	37
6.2	Description of the alarms.....	37
7.	PROGRAMMING.....	41
7.1	List of parameters	41
7.1.1	Table of parameters	41
7.2	Description of the parameters.....	43
7.2.1	Probe set-up (“S” parameters).....	43
7.2.2	Regulation set-up (“R” parameters).....	44
7.2.3	Compressor and heater activity (“c” parameters).....	45
7.2.4	Fans (“F” parameters).....	46
7.2.5	Defrost (“d” parameters)	47
7.2.6	Alarms (“P” parameters).....	48
7.2.7	General machine configuration parameters (“H” parameters).....	48
7.2.8	pLAN communication (“L” parameters)	50
8.	DIMENSIONS	51
9.	TECHNICAL SPECIFICATIONS	52
9.1	Terminal board	52
9.2	Relay power board for stand-alone units	52
9.3	Triac power board for multi-zone applications.....	53
9.4	Common characteristics for components indicated above.....	53
9.5	Protection against electric shock	53
10.	SOFTWARE UPDATING	54
10.1	Notes for the release 3.4 (and the following ones):	54

IMPORTANT WARNINGS



BEFORE INSTALLING OR HANDLING THE APPLIANCE PLEASE CAREFULLY READ AND FOLLOW THE INSTRUCTIONS AND SAFETY STANDARDS DESCRIBED IN THIS MANUAL.

This appliance has been developed to operate risk-free and for a specific purpose, as long as:

- it is installed, operated and maintained according to the instructions contained in this manual;
- the environmental conditions and the voltage of the power supply correspond to those specified.

All other uses and modifications made to the device which are not authorised by the manufacturer are considered incorrect.

Liability for injury or damage caused by the incorrect use of the device lies exclusively with the user.

Please note that the machine contains powered electrical devices and all service and maintenance operations must be performed by specialist and qualified personnel who are aware of the necessary precautions.

Disconnect the machine from the mains power supply before accessing any internal parts.

The local safety standards in force must be applied in all cases.

Disposal of the instrument:

The controller is made up of metal and plastic components. To dispose all of these components refer to the environment protection laws valid in your own country.

INTRODUCTION

Aria is an electronic controller for the management of direct expansion air-conditioning developed by Carel for the home and commercial markets.

It features a room terminal which communicates with a power board installed on the air-conditioning unit itself.

With its accurately-designed appearance, it is ideal for the sector it is used in. Another important feature of the product is its ease of use, with a large LCD display and a highly intuitive user interface.

Furthermore, unlike other existing products on the market, the connection of the actuators is handled by an electronic board located directly on the machine's electrical panel, thus avoiding the need to lay large quantities of cables to the control itself.

The serial communication allows cabling reduction between the terminal and the power board to just 2 wires.

The instrument can manage both conventional units and heat pumps with up to a 3 heating and 2 cooling stages (in a single refrigeration circuit); its operational flexibility is guaranteed by a parameter used to quickly configure the type of air-conditioning unit being controlled.

A special version is also available for multi-zone applications, in which up to 30 terminals are located in different rooms, measuring the local temperature and optionally humidity, then communicating with the control of the centralised air-conditioning unit (pCO or pCO²).

1. GENERAL CHARACTERISTICS

1.1 Functions

“Aria” is a Carel electronic microprocessor-based control designed by Carel to manage single or multi zone Air Conditioning units in residential/commercial applications. “Aria” is organized into two integrated systems: a **terminal**, installed in the room, and a **power board** for managing the actuators to be placed in the electrical panel of the Air Conditioning unit itself. The terminal is connected to the power board using a two-lead cable, thus greatly simplifying installation.

The power board is available in two different models, depending on the specific application:

- one model for the control of stand alone air-conditioning units (relay power board)
- one model for the control of a motorized damper, where “Aria” is used for zone control (triac power board).

1.2 Terminal

The terminal is the heart of the system; it is fitted with an internal probe for measuring the ambient temperature (this may be remotely-located in the duct) and can be supplied with an extra active-type probe (0/1Vdc output) for measuring the ambient humidity.

The instrument's user interface has been designed for ease of use, featuring:

- the use of a complete and large-sized liquid crystal display
- the ergonomic separation of the buttons for programming (on the side) from those used for the immediate modification of the desired temperature (set point), placed on the front
- the back-lighting of the buttons and the display, useful when there is not enough light
- a built-in buzzer (can be bypassed using a specific parameter) which signals any operating anomalies of the unit, and also follow the pressing of each button.
- The presence of an optional real time clock allows the instrument to be independently time-band programmed each of the seven days of the week. Being fitted with an independent power supply, it constantly maintains the correct time even in the case of interruption to the main power supply.

The terminal is very easy to install, as:

- just 2 leads connect the terminal to the power board
- the quick insertion terminals used allow the connection of the cables to the terminal using the rear shell of the box; the electronic parts are connected at the end, as the front panel is closed.
- the instrument may be programmed by simply copying the settings from another “master” machine, using a hardware “key”




Figure 1.2.1




Figure 1.2.2

Figs.: 1.2.1 and 1.2.2 represent respectively the rear view of the terminal and the view of the rear shell.

The following “areas” of connection can be identified on the rear shell:

- **T+**, **T-** for the connection of the power board
- **24 V**, **AVss**, **B2** for the connection of a remoted Carel external active humidity probe (0/1Vdc output);
- **AVss**, **B1** to remote the NTC temperature probe
- **Rx/Tx+**, **GND**, **Rx/Tx-** for connecting the terminal to the Carel pLAN local network

On the rear side of the terminal there are two further jumpers, J1 and J2, which are used as follows:

- **J1**: positioned between 1-2: Carel NTC temperature probe B1 remoted externally
positioned between 2-3: built in Carel NTC temperature probe B1

Note: For correct operation, do not connect the external temperature probe if the internal probe is used.

- **J2**: positioned between 1-2: probe (0/1Vdc output) B2 remoted externally
positioned between 2-3: built in humidity probe B2

1.3 Power board for the control of stand alone air-conditioning units (code TABASE5000)

This board is installed inside the air-conditioning unit electrical panel; it is fitted with a set of terminals for connection to the controlled devices (such as valves, compressors, fans). Its main features are:

- an analogue input for measuring the temperature of the external heat exchanger of a heat pump unit in order to control the defrost cycles and condenser fan; for units without heat pump, or alternatively by excluding the defrosts, it may be used as the outside temperature measurement to control free-cooling, free-heating and temperature set point compensation (see paragraph x.xx);

5 or 7 digital outputs (relays) – according to the models - which allow the instrument to be used in a wide range of applications (see H1 parameter)

- 3 multifunctional digital inputs (see 5.6)




Figure 1.3.1

The following “areas” of connection can be identified on the board:

- terminals **G** and **G0** for power supply (24Vac)
- terminals **T-** and **T+** for connection to the terminal
- terminals **ID COM**, **ID1**, **ID2** and **ID3** for connection of the digital inputs
- terminals **B3** and **GND** for connection of the NTC temperature probe on the external heat exchanger or in the outside air (see paragraph “5.2.8 Using probes B2 and B3);
- terminals **Cn-NO n** for connection of controlled devices

Jumper J3, located in the centre of the card, is available for the selection of the digital input power supply. For more details see **Installation of the relay power board (stand-alone system – see ph. 3.3)**.

The board also features a **green LED** which provides a variety of information, coded according to the number of flashes emitted in a 3 second period:

- **1 flash** every 3 seconds: normal operation
- **2 flashes** every 3 seconds: serial communication error; the power board is not receiving the data sent by the terminal
- **3 flashes** every 3 seconds: serial communication error; the terminal is not receiving the data sent by the power board

1.4 Power board for the control of a motorized damper (multi-zone system codeTAZONE0000)

This board manages the motorized inlet air damper with a 3-point control, typically in multi-zone applications. Its main features are:

- two 24Vac triac outputs to control damper opening/closing
- three multifunctional digital inputs (see 5.6);
- one analogue input, for automatic cooling / heating selection using the probe located in the air duct (see 5.2.8).

The following “areas” of connection can be identified on the board:

- **G** and **G0** for power supply (24Vac)
- terminals **T-** and **T+** for connection to the terminal
- terminals **ID COM**, **ID1**, **ID2** and **ID3** for connection of the digital inputs
- terminals **B3** and **GND** for connection of a NTC temperature probe
- terminals **OUT1**, **OUT2** and **C** to open and close the zone damper.




Figure 1.4.1

1.5 Codes

Here follow the codes of the Aria components.

Terminal	code
Terminal, basic model	TAT00000W0
Terminal, with programmer clock	TAT0000CW0
Terminal, with programmer clock, back-lit display, buzzer	TAT000RCW0
Terminal, with programmer clock, back-lit display, buzzer and built in humidity probe	TAT000HCW0
Terminal with pLAN output	TAT0000PW0
Terminal with pLAN output, back-lit display and buzzer	TAT000RPW0
Terminal with pLAN output, back-lit display, buzzer and built in humidity probe	TAT000HPW0

Tab. 1.5.1

Power boards

Description	code
Power board with 5 relays	TABASE5000
Power board with 7 relays	TABASE7000
Power board for zone control	TAZONE0000

Tab. 1.5.2

Programming hardware key

Description	code
Programming hardware KEY	TAKEY00000

Tab. 1.5.3

2. APPLICATIONS

The Aria control can be used in a wide variety of applications, which are selected using the parameter **H1**. The possible applications can be divided into two families:

- **stand-alone applications**, where “Aria” controls directly the air-conditioning units via relay power board. The power board is available in two different models, with either 5 or 7 relays (part no. TABASE5000 and TABASE7000).
- **multi-zone application control** where a series of terminals are connected to a Carel pCO programmable control using the Carel pLAN local network (pCO Local Area Network). In this situation the terminal ARIA measures the temperature and the humidity of the zone, sends the data via pLAN to the centralized machine's controller pCO or pCO2, which, depending on the information received from the other zone terminals (up to a maximum of 30), decides the operating logic and thus the temperature and humidity of the air to be introduced into the duct. Each terminal is connected to triac power board (code TAZONE0000) which manages the local zone damper (with floating control) in order to maintain the required ambient conditions.

WARNING: before modifying parameter **H1** and thus changing the type of application, the machine should be switched OFF (by keypad), as the outputs will change their function immediately after each change of **H1**.

2.1 Stand-alone applications

The list below describes the value of parameter H1 and the function of each relay for each application, using the following abbreviations:

- **C1, C2** : relay for the control of cooling stages no.1 and no.2;
- **V** : relay for the control of the reverse cycle valve;
- **R1, R2, R3** : relay for the control of heating stages no.1,2 and 3;
- **R1, R2, R3** : relay for the control of heating stages no.1, 2 and 3;
- **R1aux, R2aux** : relay for the control of auxiliary heater 1, auxiliary heater 2;
- **F1, F2, F3** : relay for the control of the supply fan at speed 1, speed 2, speed 3;
- **OP** : programmable output, via parameter H2;
- **NU** : Not Used;
- **ALL**: relay for alarm signalling;
- **ES+** : Free-cooling or Free-heating damper opening relay;
- **ES-** : Free-cooling or Free-heating damper closing relay;
- **P** : water pool pump;
- **Rp** : pool water heating element.

The OP programmable output has the following functions, depending on the value of parameter H2:

H2	OP
0	Humidifier control
1	Alarm signal
2	Control of Fan on external heat exchanger
3	optional heaters for heating the pool water
4	Functioning mode remote signal (heating or cooling)
5	Comfort set point active signal

Tab. 2.1.1

The relays can be identified by referring to the numbering in Fig. 1.3.1.

Relays 1 and 2 have normally-open (NO) and normally-closed (NC) contacts while relays from 3 to 7 only have normally-open contacts. In the 5-relay model, relays 6 and 7 are not present.

2.1.1 Heating only

	H1	RL7	RL6	RL5	RL4	RL3	RL2	RL1
1 stage heating	0	ES+	ES-	R1	NU	F1	OP	ALL
2 stage heating	1	ES+	ES-	R1	R2	F1	OP	ALL
3 stage heating	2	ES+	ES-	R1	R2	F1	R3	OP

Tab. 2.1.1.1

2.1.2 Cooling only

	H1	RL7	RL6	RL5	RL4	RL3	RL2	RL1
1 stage cooling	3	ES+	ES-	C1	NU	F1	OP	ALL
2 stage cooling	4	ES+	ES-	C1	C2	F1	OP	ALL

Tab. 2.1.2.1

2.1.3 Conventional

	H1	RL7	RL6	RL5	RL4	RL3	RL2	RL1
1 stage cooling / 1 stage heating	5	ES+	ES-	C1	R1	F1	OP	ALL
1 stage cooling / 2 stage heating	6	ES+	ES-	C1	R1	F1	R2	OP
1 stage cooling / 3 stage heating	7	ES+	ES-	C1	R1	F1	R2	R3
2 stage cooling / 1 stage heating	8	ES+	ES-	C1	C2	F1	R1	OP
2 stage cooling / 2 stage heating	9	ES+	ES-	C1	C2	F1	R1	R2
2 stage cooling / 3 stage heating	10	C1	C2	F1	R1	R2	R3	OP

Tab. 2.1.3.1

2.1.4 Heat pump

	H1	RL7	RL6	RL5	RL4	RL3	RL2	RL1
single-compressor	11	ES+	ES-	C1	F1	R1 _{AUX}	V	OP
dual-compressor 1Raux, 1 circuit	12	C1	C2	F1	R1 _{AUX}	OP	V	AL
dual-compressor 2Raux, 1 circuit	13	C1	C2	F1	R1 _{AUX}	R2 _{AUX}	V	OP

Tab. 2.1.4.1

2.1.5 Split system

	H1	RL7	RL6	RL5	RL4	RL3	RL2	RL1
single compressor heat pump	14	C1	R1 _{AUX}	F1	F2	F3	V	OP

Tab. 2.1.5.1

2.2 Multi-zone control

This application can be selected by setting parameter H1=15; referring to Fig. 1.4.1, the meaning of the outputs is the following:

	H1	OUT1	C	OUT2
zone controller	15	Open	Common	Close

Tab. 2.2.1

2.3 Display terminal

This application can be selected by setting parameter H1 = 16 and allows you to use the terminal as a display unit to measure the temperature/humidity, connected to a pCO via pLAN serial line. There is no need then to use any Aria power card (neither TABASE* nor TAZONE*).

2.4 Pool environments

	H1	RL7	RL6	RL5	RL4	RL3	RL2	RL1
climate and pool water control	17	C1	C2	R	F1	P	Rp	OP

Table. 2.4.1

2.5 Heat pump + Energy Saving

	H1	RL7	RL6	RL5	RL4	RL3	RL2	RL1
dual-compressor heat pump with energy saving	18	C1	C2	F1	ES+	ES-	V	OP

Table. 2.5.1

2.6 Split cooling only

	H1	RL7	RL6	RL5	RL4	RL3	RL2	RL1
dual-compressor heat pump with energy saving	19	C1	-	F1	F2	F3	-	OP

Table. 2.6.1

3. INSTALLATION

3.1 Terminal installation

For correct installation, the following warnings must be heeded:

- always disconnect the power supply before performing any operations on the board during assembly, maintenance or replacement.
- the terminal must be mounted vertically, allowing for air to circulate through the instrument's vent-holes. Avoid places where the measurement of the ambient temperature by the internal sensor may be altered, such as outside walls, near doors leading outside, in direct sunlight, etc.
- the cables for connection to the power board must be kept separate from other cables, using an individual raceway and, possibly, shielded cables. In such a case connect the cable braid to terminal G0, reference for the 24Vac power supply (leave the other side of the braid free). The maximum length allowed is 150m, according to the section of the cable, as per the table:


length of connection (m)	minimum cross-section (mm ²)
0 - 50	0.5
50 - 150	1

Tab. 3.1.1

- when making the connection to the power board special attention must be paid to the polarity; the T+ pin on the terminal side must be connected to the T+ pin on the power board; similarly for the T- pin (however in case the cables are connected in the opposite order the instrument will not be damaged).

The installation procedure is the following:

1. To detach the front panel of the terminal from the rear shell, place a flat-heat screwdriver in the slot in the centre of the bottom side of the housing and release the locking flap (Fig. 3.1.1).
2. Raise the front panel using a "hinge" movement, using the upper edge of the instrument as the pivot and raising the lower edge (Fig. 3.1.1);
3. To mount the rear shell to the wall, place the hole in the centre of the shell over the control cables of the instrument which come out of the wall. The placement of the mounting holes has been designed to allow the instrument to be fixed onto standard European flush mounting boxes conforming to standards CEI C.431 - IEC 670. If this is not available, use the mounting holes on the shell as a guide for drilling holes into the wall and then use the screw and plug kit supplied.
4. Connect the cables to the terminals on the rear shell of the terminal, as indicated in Fig. 3.2.1 or Fig. 3.4.1, according to the application you are facing to (stand alone or multi-zone).
5. Check the correct installation of the two jumpers J1 and J2 located on the rear side of the terminal (see Fig. 1.2.1)
6. Finally, close the instrument, moving the front panel onto the rear shell with a "hinge" movement, in the opposite way as used for opening. First the long side of the front panel near the display is snapped onto the rear shell, then the opposite side, being careful that the terminal pins slide into their corresponding female terminals.



3.2 Connection diagrams for stand-alone applications

In Fig. 3.2.1 is shown the connection diagram for stand-alone type applications.




Figure 3.4.1

3.3 Installation of the relay power board (STAND ALONE system) and multi-zone power board

The power board may be installed on the electric panel of the air-conditioning unit to be controlled. Its dimensions, DIN standard compatible, allow installation on omega rail by means of suitable adapters available on the market. Connect the actuators as in Fig. 3.2.1; the relays no.1 and no.2 have dual contacts, while the others have only one contact, normally open. For a description of the devices controlled by each relay please refer to the **Applications** (pg. 7), according to the specific configuration of the machine.

The digital inputs ID1, ID2, and ID3 are optically insulated and suitable for 24Vac/dc signals with “normally closed” logic (at the contact opening there is alarm condition). To simplify the wiring it is possible to get the 24Vac/dc power supply from the GND terminal (see Fig. 3.3.1). In fact J3 jumper can be placed as follows:

- J3:**
- in position 1-2 (**INT - ID COM**): digital inputs powered internally (Fig. 3.3.1);
 - in position 2-3 (**ID COM - EXT**): 24Vac/dc power supply to be provided by the user (Fig. 3.3.2).

In order to get a real optical insulation, digital inputs power supply must be different from the one on the board that is 24 Vac/Vdc. In case the digital inputs are supplied by direct current, the IDCOM terminal must be connected to the positive pole, ID1, ID2 and ID3 to the negative one.




Fig. 3.3.1




Fig. 3.3.2

For correct installation the following warnings must be heeded:

- always disconnect the power supply before performing any operations on the board during assembly, maintenance or replacement.
- the cables for connection to the power board must be kept separate from other cables, using an individual raceway and, possibly, shielded cables. In such a case connect the cable braid to terminal G0, reference for the 24Vac power supply (leave the other side of the braid free). The maximum length allowed is 150m, according to the section of the cable, as per table 3.1.1.
- when making the connection to the power board special attention must be paid to the polarity; the T+ pin on the terminal side must be connected to the T+ pin on the power board; similarly for the T- pin (however in case the cables are connected in the opposite order the instrument will not be damaged).

For the multi-zone power board (TAZONE0000), follow the same **correct installation procedure** for the relay power board.

3.4 Connection diagrams for zone control applications

The triac power card is to be installed on a omega DIN rail. Connect the cards as follows:




Figure 3.4.1

For a detailed description of the pLAN local network usage refer to the respective guide (pLAN technical guide); the connection to the pCO / pCO² is as follows:




Figure 3.4.2

4. USER INTERFACE

In Fig. 4.1 are shown the buttons and the indications managed by the terminal.




Fig.4.1

4.1 Meaning of the symbols on the display




Fig. 4.1.1

In particular:

- the ❄️ symbol always on indicates actuators active in cooling mode.
- the 🔥 symbol always on indicates actuators active in heating mode.

If either symbol is flashing, this indicates that the actuators should be activated, yet external causes prevent them from doing so (timers, alarms etc.). For a detailed description of the other symbols please refer to the paragraphs on the **Description of the button meaning** and **OPERATION**

4.2 Description of the button meaning

4.2.1 Front and Side buttons

The front buttons are the most important and thus are easier to reach, being large and placed on the front panel of the instrument. These allow the immediate setting of the desired temperature (set point).

The side buttons allow access to all the other functions of the control. Immediate programming

4.2.2 Programming

4.2.2.1 F Button [^] and Button [v]

The [^] and [v] buttons allow the increase/decrease of the current set point by 1°F or 0.5°C.

Specifically, in time-band operating mode (indicated by the clock symbol), pressing the [^] and [v] buttons temporarily modifies (overrides) the current set point. The duration, in hours, is shown at the bottom of the display and being decreased every hour until the preset value elapses (parameter H8); the controller will then return to the previous operating mode (time bands).

During the modification phase the display shows the temperature set point, on the large display in the top left, in the place of the measured temperature, if this is not already displayed on the small display in the top right (this function can be selected using parameter H7)..

Modifications are acknowledged by the controller 5 seconds after releasing the buttons, when the related symbol stops blinking.

4.2.3 Selecting the machine's operating mode ([MODE] button)

Aria allows different operating modes of the air handling unit described below:

- **OFF**: the thermostat does not perform any control: however, it prevents the temperature from dropping below the safety low limit(see paragraph 4.2.4.1);
- **COOL**: the thermostat controls cooling only;
- **HEAT**: the thermostat controls heating only;
- **AUTO**: heating and cooling control (automatic). The system switches from one function to the other depending on the value of the ambient temperature in respect to the set point;
- **FAN**: ventilation only; you select the operating mode of the supply fan among 1, 2, 3, AUTO and OFF by means of the [FAN] button.

If you press the MODE button in the time-band operating mode, it displays the current operating mode for 5 seconds (indicated by the corresponding blinking writing in the place of the clock). In the manual operating mode, instead, the operating mode is always shown.

By pressing the button repeatedly the possible operating modes for the machine selected alternates.




Fig. 4.2.4.1

The operating mode selected is acknowledged 5 seconds after setting, when the related symbol stops blinking.

4.2.3.1 Selects the supply fan operating mode ([FAN] button, stand-alone version only)

Depending on the number of the supply fan speeds available and the machine operating mode, the FAN button scrolls through the following modes:

- **OFF**: supply fan off (available only when in simple ventilation)
- **1**: supply fan constantly at speed 1
- **2**: supply fan constantly at speed 2
- **3**: supply fan constantly at speed 3
- **AUTO**: supply fan switched on and off along with the actuators


When selected speed 1, 2 and 3, the symbol corresponding to the selected speed lights up for 5 seconds. Afterwards, the number corresponding to the actual operating speed lights up; it may temporary differs from the one selected due to parameter c8 (delay when varying the speed rates of the supply fan). Having set AUTO operation, when the fan starts, the text AUTO also appears next to the fan symbol.

For details, see **Output management**.

4.2.4 Setting the temperature and humidity set points




4.2.4.1 Setting the temperature set point category ([SET] button)

There are 3 possible “situation” available (unoccupied, comfort, night-time) indicated by the relative symbols, as well as the “machine OFF” limit category:

- comfort set point (indicated by the symbol 


Pressing the SET button in manual operating mode (without clock) changes the category currently used by the control. In time-band operating mode, on the other hand, the category is automatically set by the current program, as previously saved.


If [^] and [v] are pressed within 5 seconds of pressing SET (when category symbols are flashing) the set points of the selected category can be modified. The default values for the various categories are:

category	set (°C / °F)
	21 / 70
	±2 / ±4
	±4 / ±7

Tab. 4.2.5.1.1

Graphically the regulation obtained in the three different situations (and in AUTOMATIC operating mode) is the following:



When the unit is turned off (symbol  visualized in the display) or on in MODE=FAN, Aria will still start the heating stages whenever ambient temperature drops below the low limit set with parameter P4 (Carel default value is= 10°C) in order to avoid any damage in the room. In any case, this anti-freeze function can be excluded using parameter R14.

The right value of each category is related to the season and the personal idea of “comfort” of each user.

4.2.4.2 Setting the humidity set point ([SET] button for 3 seconds)

This can only be modified if the presence of the humidity probe has been enabled, using S1=2. The set point is modified using the [^] and [v] buttons (modifications are acknowledged by the controller 5 seconds after releasing the buttons). The humidity set point can also be set by parameter R5.

4.2.5 Programming the parameters

The user has numerous parameters available to customise the operation of the control, making it adaptable to a wide range of needs and applications. The parameters have been divided into 3 levels:

1. **DIRECT (D):** directly accessible without protection code;
2. **USER (U):** accessible with protection code (installer level);
3. **FACTORY (F):** accessible with protection code at factory level (manufacturer level).

4.2.5.1 Setting the DIRECT parameters ([SET]+[HOLD] buttons)




Fig. 4.2.6.1.1

The display shows the first of the main machine operating parameters available. The parameters are scrolled using the [^] and [v] buttons. Once having selected the parameter to be modified, proceed as follows:

- press the SET button to enter modifying mode, the selected parameter flashes;
- press the [^] and [v] buttons to modify the value of the parameter;
- press the SET button to confirm the modification.

To exit programming mode and accept the modifications to the parameters, press the HOLD button.

To exit programming mode, and NOT accept the modifications to the parameters, press the RESUME button, or wait for 1 minute of inactivity (the final 15 seconds are signalled by the flashing of the characters on the display).

4.2.5.2 Setting the USER parameters (installer, [SET]+[MODE] buttons)

These are the machine's "working" parameters, and are password-protected to avoid access by non-authorized persons. First of all the access code 22 must be entered using the [^] and [v] buttons and confirmed using the SET button; when setting the code, the right display shows the text U3r, telling the user what branch they are in.



Fig. 4.2.6.2.1

Proceed then as per the setting of the DIRECT parameters.

The USER parameters also comprise the DIRECT parameters. The USER-only parameters are signalled by the key symbol.




Fig. 4.2.6.2.2

Pressing the MODE button during the modification of a parameter enables a DIRECT parameter to become a USER parameter and vice-versa. On displaying the parameter in question the key symbol will appear or disappear.

4.2.5.3 Setting the FACTORY parameters (configuration, [SET]+[MODE] buttons for more than 3 seconds)

These are the machine's configuration parameters. They are protected by a separate code from the USER code, to allow only specific persons to access the data. First of all set the access code 177 using the [^] and [v] buttons, and confirm it using the SET button; when setting the code, the right display shows the text Fac, telling the user what branch they are in.

Proceed as per the other parameters.

4.2.5.4 Setting the default parameters ([SET] + [RESUME] buttons when powering the controller)

These are pressed before switching on the machine and held until the settings have been entered, as signalled by the script 'dEF' displayed for 5 seconds. This operation allows the automatic setting of all the parameters contained in the Table 7.1.1 at their default value (column "def" of the same table) except for the following parameters: S1, S2, S3, R8, R14, R18, R27, F7, F8, F9, F10, F11, F12, F13, H1, H2, H15, H16, P12, d12.

4.2.6 Using the Hardware key

4.2.6.1 Copying parameters from the removable hardware key to the controller ([SET]+[^] buttons when powering Aria or even only [^] button when powering Aria)

At the start of the operation the script “CE” appears; at the end “OK” or “NO” appears, according to the result of the data transfer.

4.2.6.2 Copying parameters from the controller to the removable hardware key ([SET]+[v] buttons when powering Aria)

At the start of the operation the script “EC” appear; at the end “OK” or “NO” appear, according to the result of the data transfer.


4.2.7 Real time clock and time-bands

4.2.7.1 Setting the time ([CLOCK] button, version with built-in clock only)

The value to be modified, that is, hours, minutes and day of the week, is selected by pressing CLOCK repeatedly, modified using [^] and [v], and confirmed by pressing CLOCK again.

Pressing RESUME or after 60 seconds of inactivity, normal mode is resumed, and the modifications entered are lost.

4.2.7.2 Time bands

The time bands are the intervals of time into which a 24 hour day is divided; in each band, the operating mode of the unit can be selected, between:  -

There are 6 possible time bands for each of the 7 days of the week.

When programming the time bands, these are indicated respectively by the letters t1-t2-t3-t4-t5-t6 on the small display in the top right. When selecting one of the symbols, that is, comfort, night-time or unoccupied, for a time band, the unit will maintain the set temperature value throughout the interval of time in question.

If selecting the Standby symbol for a time band, the unit will switch off throughout the interval of time in question. If a set point category symbol (comfort, night-time, unoccupied) has then been selected for the following time band, the unit will automatically switch back on. When a Standby time band is active, if the unit has not already been switched off using the Mode button, the Standby symbol will blink.

Digital input ID3, if used as a serious alarm, does not have any effect if Aria is “OFF”, either due to the time bands or using the Mode button. The unit can be temporarily activated during a Standby time band by pressing the Hold button (see par. 4.2.8.1). Pressing Resume returns to the Standby time band (see par. 4.2.8.2).


4.2.7.3. Setting the time bands ([CLOCK] button more than 3 seconds)

The time bands refer only to temperature and not humidity regulation which is always based on the same set point.

The choice among the symbols is always highlighted by having the currently selected symbol flash and leaving the other symbols constantly on; [^] and [v] are used to change the selection, making the next symbol in the sequence flash. To confirm the selection and pass to the following field use the CLOCK button.

To set a program, after having pressed the CLOCK button for more than 3 seconds, the following steps must be performed:

- set the program start day
- set the start hour and minutes for the first band
- set the temperature set point category for the band
- after programming the band the symbols to ‘continue’ (<-->) and ‘end’(-->) appear, accompanied by the words “cont” and “end”
- ‘cont’ scrolls cyclically to the other bands, setting the start hours and minutes for the second band and so on (the current band ends when the successive one starts)
- ‘end’ stops the programming for that day (thus cancelling any unprogrammed bands)
- after ‘end’ or after having programmed the final band for the current day, the day of the week programmed flashes followed by the word ‘copy’. Use [^] and [v] to scroll to the other days, which flash in turn, confirming the day using the CLOCK button, thus extending same program to the selected days. The symbols ‘cont’ (flashing) and ‘end’ and the script “cont” and “memo” appear on the alphanumeric field
- use ‘memo’ to exit from programming mode and enable time-band operation. If there are days which have not been set, these continue to use the previous program. On pressing the RESUME button, on the other hand, or after 1 minute of inactivity, the modifications entered are lost.
- use ‘cont’ to program the remaining days

The time interval identified by time current band is shown on the display using the clock symbol, divided into 1-hour sections. Thus, the time band from 3 to 7 o'clock is indicated as follows 

4.2.8 Alarm management and general functions

4.2.8.1 [HOLD] button.

This button has the following functions:

- exits the parameter programming phase, saving the modifications entered;
- on models with built in clock it passes from time-band to manual operation; in such a situation the word “HOLD” appears and the comfort set point resumed, independently from any previous operating Set Point.

4.2.8.2 [RESUME] button.

This button has the following functions:

- exits from the current programming phase without saving the modifications;
- exits from overriding the set point in time band operation (models with real time clock);
- exits from manual operation (HOLD) and returns to time band operation (models with real time clock);
- resumes the comfort set point on models without real time clock;
- silences the buzzer.

4.2.8.3 [RESUME] button for more than 3 seconds

Manually resets the active alarms, cancelling the message on the display and de-energizing the alarm relay, if the alarm conditions do not persist any more.

4.2.8.4 [^] + [v] buttons simultaneously

This displays a value marked R SP in the lower display; the value corresponds to the effective start-up temperature of the devices in the current situation. For example, in cooling operation with Comfort Set=21.0°C, Night-time Set=4.0°C (active), and a compensation of +2.0°C, the effective start-up point of the compressors is 27.0°C, that is, the value displayed by R SP. This may be useful in the test phase.

The firmware version is displayed by holding the arrow buttons for more than 3 seconds.

5. OPERATION

5.1 General

The term SET POINT refers to the point which sets the position of the control's working range within the interval of measurement of the value being regulated. The set point thus identifies the regulation value (temperature or humidity) that the control aims to maintain.

The term DIFFERENTIAL, on the other hand, refers to the value assigned to the control's working range. Thus choosing a narrow differential means that the control will operate very close to the set point, with minimum variance from the set value, yet this also means an increase in the number of interventions of the control, thus reducing the life-span of the system's components. Vice-versa, choosing a differential which is too wide, while providing system stability, means that the values reached during regulation may vary greatly from the set point. The terms DIRECT and REVERSE indicate the two types of regulation logic for the device. The control uses "direct" logic when the controlled measurement (e.g. temperature or humidity) tends to increase, aiming to reach the desired value (set point) (e.g. cooling, dehumidification); it uses "reverse" logic when the controlled measurement tends to decrease, aiming, again, to reach the desired value (set point) (e.g. heating, humidification). Automatic (AUTO) operation refers to when the device works in both "direct" or "reverse" logic according to the value of the controlled measurement in respect to the set point.

The regulation set point for the "Aria" control is a "lateral band" type, that is the band identified by the differential is aside the set point, graphically on the right or on the left of the set point (if we are respectively cooling or heating). Normally the actuators are deactivated when the value of the controlled measurement is equal to the set point. For temperature regulation it is however possible to define a zone centred around the set point, called the "Neutral zone" (see Fig. 5.1.1), inside of which the actuators are already deactivated. This type of regulation is proportional. The stand-alone version can also perform Proportional + Integral regulation (selected by parameter R19).




Figure 5.1.1

5.2 Stand-alone version

5.2.1 Proportional regulation algorithm

For the models with 1 regulation output, in "direct" operation without neutral zone 5.2.1.1, Aria activates the output when the controlled measurement exceeds the value of set point+differential and the output remains ON until the controlled measurement decreases to the value of the set point. In "reverse" operation, still without neutral zone (Fig. 5.2.1.3), the device activates the output when the controlled measurement falls below the value of set point-differential and the output remains ON until the controlled measurement rises to the value of the set point.




Fig. 5.2.1.1




Fig. 5.2.1.2

The Fig. no. 5.2.1.1 and 2 show respectively: direct without neutral zone and direct with neutral zone.

In AUTO operation (Fig. 5.1.1) the device can operate in both "direct" and "reverse" modes.. If the system has one or two auxiliary heaters, these (if enabled) are activated according to the value of Haux set point (relative to the current temperature set point) less the eventual neutral zone.




Fig. 5.2.1.3




Fig. 5.2.1.4

The Fig. no. 5.2.1.3 and 4 show respectively: reverse without neutral zone and reverse with neutral zone.

For the models with 2 regulation outputs, in “direct” operation without Neutral zone (Fig. 5.2.1.5) the device activates the first output (OUT1) when the controlled measurement exceeds the value of set point+1/2 differential; the second output is then activated (OUT2) when the measurement exceeds the value of set point+differential. The outputs remain ON until the controlled measurement falls below the value of set point+1/2differential (OUT2 goes off) and set point (OUT1 also goes off). In “reverse” operation without Neutral zone (Fig. 5.2.1.7) the device activates the output OUT1 when the controlled measurement falls below the value of set point-1/2 differential; output OUT2 is also activated if the measurement falls below the value of set point-differential. The outputs remain ON until the controlled measurement reaches the value of set point-1/2 differential (OUT2 goes off) and set point (OUT1 goes off too).




Fig. 5.2.1.5




Fig. 5.2.1.6




Fig. 5.2.1.7




Fig. 5.2.1.8




Fig. 5.2.1.9

The Fig. no. 5.2.1.7 and 8 show respectively: reverse without neutral zone and reverse with neutral zone.

In Fig.5.2.1.9 provides a description of a heat pump unit with 2 compressors and 1 auxiliary heater in AUTO operation, with the following parameter settings: R1=18, R3=6, R4=2, R8=6, R9=2.

Humidity regulation (Fig.5.2.1.10) is very similar to the temperature one; humidification (=reverse) is driven by a single stage (relay OP, programmed accordingly, H2=0) while dehumidification is performed by the available cooling stages which, according to the model, may be 2. Graphically a 2 compressor unit with relay OP programmed to drive an humidifier is hereafter indicated:




Fig. 5.2.1.10

Neutral zone is not available on humidity control.

5.2.2 Proportional + Integral regulation algorithm

If system's point of equilibrium is required to correspond to the value of set point, more sophisticated regulation must be imposed. Integral-type regulation must be added to proportional regulation (available as standard). Integral-type regulation acts on the variation of the point of equilibrium from the set point, aiming to reduce this to zero. The integral time must be set; a typical value for this parameter, recommended as an initial setting, is 600 seconds (10 minutes). The integral error is not calculated at all points of regulation, but rather only when the measurement is located in the zone identified by the differential plus 10%. Outside of this zone, proportional regulation only is performed.

Once PI regulation is activated, the control increases the integral error, which is added to the proportional error, in every instant: this means that the instrument is constantly acting to reduce the total error being accumulated, with the result that the point of equilibrium is continuously being brought nearer to the required set point.

5.2.3 Split operation

The machine model H1=14 allows the management of split-type units, that is single-compressor heat pump with the possibility to manage a three-speed supply fan in the internal exchanger. The ability to modify through ventilation the overall capacity - 0÷100% - of a single compressor based unit has led to the development of temperature control which is different from the one available on the other selectable machine models (parameter H0). Given the set point and the differential, the following control logic has been preferred, considered as being more efficient:




Fig. 5.2.3.1

The compressor is in fact switched on at 50% of the temperature differential (both in heating and cooling), with the supply fan already on at minimum speed; if the temperature continues to rise the fact of switching the supply fan to speed two at 66% and speed three at 100% of differential allows the temperature to be smoothly brought back within the set point.

This system has the following advantages:

- on minimum temperature variations the supply fan is started (if it has not be set for continuous operation) at minimum speed, circulating the air in the environment, overcoming any stratification of the air and providing a certain level of comfort.
- The compressor starts-up at 50% of the differential and no longer at 100%, thus accelerating the overall response of the machine to changes in ambient temperature.
- When the compressor is running there are two further supply fan steps which allow modulation of the refrigeration power, both on increase and decrease of the temperature. In practice, the efficiency of the machine is optimised accordingly the variation of thermal load.

This logic is of course valid in heating, cooling and automatic operating modes. In addition, the neutral zone function is still available, if necessary; when enabled the start-up point of the compressor is "moved" away from the set point of the value of the neutral zone (as for other operating modes).

The supply fan is driven using 3 contacts, RL3, RL4 and RL5, activating the different speeds in mutual exclusion:




Fig. 5.2.3.2

- at minimum speed only relay RL5 is energised
- at medium speed relay RL5 is de-energised and relay RL4 is energised
- at maximum speed relays RL4 and RL5 are off and relay RL3 is energised.

The reverse sequence is adopted for switching off.

The configuration H1=19 is a variation of H1=14, where the reverse cycle valve and the heating element are absent; that is, a cooling-only unit.

5.2.4 Defrost management

The defrost process (enabled if parameter d1=1) is activated in the heat pump units during heating, when the outside temperature is very low and the coil of the external heat exchanger is getting frozen. The start of the defrost is determined by the drop in the temperature of the external coil (measured by probe B3) below a certain threshold (parameter d3) for a minimum time (parameter d5) and brings about the immediate shut-down of the external and supply fan and the inversion of the reverse cycle valve; the compressors remain on. If enabled by parameter d8, the auxiliary heaters are also activated; in this case the internal fan remains on. The end of the defrost may be based on time (parameter d2=0) or determined by the return of the temperature (parameter d2=1) of the evaporator above a certain threshold (parameter d4) or by the opening of digital input ID3 (parameter d2=2), in any case it must end within a maximum time period (parameter d6). The minimum interval between two defrost cycles is set by parameter d7.

5.2.4.1 Forced defrost due to low outside temperature

If the temperature of the condenser (probe B3) falls below a certain temperature value (d11), even if the minimum time between two defrosts has not elapsed (d7), a defrost is performed in any case. At the end of the defrost, the time d7 restarts. The program may not perform more than one forced defrost at a time, and in fact after having ended the first, it waits for the end of the time between two defrosts, even if the outside temperature B3 is lower than d11. Note that the forced defrost is valid if the start temperature d11 is lower than the normal setting, d3.

5.2.4.2 Manual defrost

Parameter d13 can be used to activate a manual defrost, if the unit is operating in PdC mode. The defrost can be ended by using parameter d13 again (setting it to 0) or alternatively when a temperature is reached (d4), or a maximum time elapses (d6), or by pressure switch on a digital input; in the latter three cases parameter d13 changes from 1 to 0 automatically.

5.2.4.3 Compressor stops at start and end defrost

The compressor can be stopped at the start and the end of the defrost cycles. The defrost start sequence is the following:

1. defrost request
2. stop compressors
3. wait time d9
4. reversing valve
5. wait time d10
6. compressor starts and defrost is performed.

The end defrost sequence is the following:

1. end defrost reached
2. stop compressors
3. wait time d9
4. reversing valve
5. wait time d10
6. compressor starts (if required by the system).

If one of the two times d9 or d10 is equal to 0, the compressor is not stopped at the start or at the end.


5.2.4.4 Supply fan activation delay after defrost

If a defrost is performed without the support heaters (d8=0), the supply fan remains off. To prevent the fan from starting immediately at the end of the defrost, sending cold air into the room, this can be delayed from the start of the compressors by a time set using parameter F13.

5.2.4.5 Smart defrost cycles

The minimum time that must elapse between two defrosts, d7, can be automatically decreased if the defrost requests are so frequent that the time d7 is considered too high. The time d7 is decreased if two successive defrosts are started when the time d7 has already elapsed, that is, were already requested by the system before the time elapsed, but were waiting for the start signal. From this moment on, the time d7 is further decreased for each defrost that starts when the time has already elapsed. Vice-versa, d7, after having been decreased, is increased a little at a time if the defrosts do not start so frequently, that is, are requested some time after the time d7 has elapsed. The parameter defining the value that the time between defrosts is increased or decreased by is d10, and is expressed in minutes. The time between defrosts may be decreased by a maximum of 60% of the set value; if, for example, d7=20 minutes, it may be decreased by a maximum of 12 minutes, and the minimum value it may assume is 8 minutes;

it cannot be decreased below this level. If $d10=0$, the function is disabled. When switching Aria off and on again, or after a blackout, the time $d7$ is reset to its original value. Below is a time diagram relating to the intelligent defrost function, and to the compressor stops; as can be seen, the temperature at the end of the defrost cycles is below the activation threshold two consecutive times, which therefore causes the time $d7$ to be decreased.



5.2.5 Dehumidification management

The process of dehumidification is initiated by activating the cooling actuators when the ambient humidity exceeds the humidity set point + the corresponding differential, as described for “direct” operation.

In case two stages for cooling are available, the first one is engaged at 50% differential, the second one at 100%.

The process can only occur if:

- the machine selected is a conventional one, with cooling (compressors) and heating actuators (heaters), that is when parameter H1 has a value between 5 and 10
- the process has been enabled (parameter R7=1)
- the humidity probe is present (parameter S1=2)
- the temperature does not fall below the set point - differential - possible neutral zone -0.5°C (priority is given to temperature regulation). In such event, the process of dehumidification is interrupted to allow the ambient temperature to return to the set point value; following this the process of dehumidification may recommence.

If more two compressors are available and compressors rotation has been enabled, the actuator to be activated by the dehumidification process is determined as described in the section about paragraph **Output management** and under the heading **Compressor rotation**.

In the event of cooling calls along with dehumidification requests, the number of cooling stages energized will vary according the higher of the two requests.

Whenever in dehumidification process, the symbol of “ice” will lit (only if any of the heating actuators are not energized yet).


5.2.5.1 Dehumidification in Night-time or Unoccupied mode

In order to save energy, it may be useful to exclude dehumidification during the night or in periods when the environment being climate controlled is unoccupied. To do this, use parameter H15. If $H15=0$ with the Night-time or Unoccupied set point active, dehumidification is not performed. If $H15=1$ dehumidification is performed.

5.2.5.2 Dehumidification stop temperature


Dehumidification is in essence a cooling function that may lower the ambient temperature. To prevent the temperature from decreasing too much, a minimum temperature value is used to disable dehumidification. This limit is: (Comfort Set-Differential- 0.5°C); below this temperature value, dehumidification is deactivated until the temperature reaches the Comfort set point. The support heaters can be activated during dehumidification to increase the temperature; for all types of active set point (Comfort, Night-time or Unoccupied) with dehumidification enabled, the heaters are activated immediately below the Comfort set point, in order to keep the temperature high.

The diagram below refers to the situation with the Night time or Unoccupied set point active and dehumidification active. The white steps refer to the normal activation thresholds of the heaters based on temperature (away from the set point due to the dead band), while the grey steps indicate the activation of the heaters in the special case of dehumidification.



5.2.6 Automatic set point compensation

The temperature set point can be modified automatically based on the outside temperature value. If the outside temperature reaches values that may affect the operation of the unit, for example, temperatures above 40 degrees in summer, the set point is “worsened”, that is, increased; in this way, the level of comfort is decreased, yet this has a positive effect on energy savings and the life of the machine. Another use of compensation is to maintain a maximum difference between the ambient temperature and the outside temperature, to prevent, for example in shops, large differences between the outside and the inside and consequent irritation to those who enter and exit. The function is described in the following diagram:



Cooling compensation starts when the outside temperature is greater than: $\text{Set point} + R3 + 4^\circ\text{C}$. Following the example in the diagram, with $\text{Set} = 25.0^\circ\text{C}$ and $R3 = 3.0^\circ\text{C}$, the compensation starts when the outside temperature is greater than 31.0°C (cooling compensation) and less than 18.0°C (heating compensation). The intensity of the compensation can be set using parameters R23 and R24; these represent coefficients, and the higher their value, the lower the compensation for the same outside temperature variation. For example, setting $R23 = 1$ leads to a 1.0°C increase in the set point for each 1.0°C increase in the outside temperature; setting $R24 = 2$ leads to a 0.5°C decrease in the set point for each 1.0°C decrease in the outside temperature. Setting R23 or R24 to zero disables the corresponding compensation.

The maximum set point increase and decrease values are set using parameters R25 and R26.

The function is enabled using parameter H16.

N.B. For the correct use of the external probe, see the paragraph: **Using probes B2 and B3.**

5.2.7 Free-cooling & Free-heating

The terms Free-cooling and Free-heating refer to the introduction of outside air into the climate controlled environment, in favourable temperature conditions, to either heat or cool the environment and save energy. The outside air is introduced into the room by modulating the degree of opening of a damper, controlled by two relays, one for opening and one for closing. The relay activation time is the total damper stroke time (parameter L4). Whenever the control requests the total closing or opening of the damper, the system increases the energising time of the corresponding relay by 25% to ensure complete closing or opening. At each start-up, e.g. switching from Off mode to Auto mode, and whenever Aria is powered, the damper is immediately fully closed.

Different options can be chosen (parameter R27): free-cooling only, free-heating only, both enabled, and in addition with or without compressors. The with or without compressors option indicates that the compressors can or cannot start during free-

cooling / free-heating. In any case, if the outside temperature conditions are not favourable, the free-cooling and free-heating functions are not activated and the compressors start normally.

The outside temperature is favourable for the activation of Free-cooling if: Outside air temp. $<$ (Ambient temp. $- R28$)

The outside temperature is favourable for the activation of Free-heating if: Outside air temp. $>$ (Ambient temp. $+ R28$)

$R28$ defines the minimum differential between the outside and inside temperature.

The following diagrams explain this type of operation.

Diagram of free-cooling and free-heating operation without compressors ($R27=1,2,3$); it is assumed that the outside conditions are favourable. As can be seen, the damper modulates across the entire amplitude of the temperature differential $R3$, completely replacing the compressors.





Diagram of free-cooling and free-heating operation with compressors ($R27=5.6.7$); it is assumed that the outside conditions are favourable. As can be seen, the damper modulates across the entire amplitude of the temperature differential, but if the ambient temperature increases or decreases to a value of $2 \cdot R3$ above or below the set point, the compressors will start.



To prevent the introduction of outside air when the temperature differs too much from the ambient temperature, there is a maximum value for the difference between the two that, if exceeded, disables the free-cooling and free-heating functions (parameter $R29$); the functions are reset when the outside temperature is at least 2°C within the limit $R29$.

N.B. For the correct use of the external probe, see the ph. **5.2.8 Using probes B2 and B3.**

5.2.8 Using probes B2 and B3

Three probes can be connected to ARIA: two NTC temperature probes (B1 and B3) and one active humidity or temperature probe (B2). The first NTC probe, B1, is designed to measure the ambient air temperature.

The use of probes B2 and B3 changes automatically according to the functions chosen.

ACTIVE DEFROSTS ($d1=1$) ON UNIT PDC
AND/OR ACTIVE CONDENSATION (F7 different from 0)

Probe B3 is used for the defrost function and/or to manage the condensation.

Probe B2 is used to measure the humidity if $S1=2$; Compensation, Free-cooling and Free-heating can not be enabled.

Probe B2 can be used as the outside temperature measurement if $S1=1$; in this case the Compensation, Free-cooling and Free-heating functions can be enabled.

NEITHER ACTIVE DEFROSTS OR CONDENSATION

Probe B3 may be used as the outside temperature measurement; Compensation, Free-cooling and Free-heating can be enabled, Probe B2 can be used to measure the humidity.

5.2.9 Output management

Compressor management.

When powering the controller, the compressor/s are activated after an initial delay, set by parameter R21. During the normal operation the optimisation of the starting is managed using an intelligent activation program, as follows:

- - when a compressor is activated, it is not shut-down within a minimum running period (parameter c1);
- - once the compressor has been shut-down, it is not re-activated within a minimum stop period (parameter c2);
- - a set time interval must elapse between two successive start-ups of the same compressor (parameter c3).
- - the second compressor, if present, may only be started after a set interval (parameter c4) from the starting of the first compressor;
- - when there are 2 compressors, compressor rotation is enabled if parameter R18 is set to 1.

Compressor rotation. Compressor rotation is a system which controls compressor activation in such a way as to equalise their operating times. The operating logic when 2 compressors are activated is that the first to be started/stopped is the first to be stopped/started. When just one compressor is activated (in a system with 2 compressors) this is done by alternating the compressors used. After a certain operating period, set by parameter c7, the compressor maintenance required message is displayed.

Reversing cycle valve management

This is controlled by the HEAT/COOL/AUTO setting on the terminal or by digital input ID1 in the heat pump units.

Heat: heating mode, valve de-energized

Cool: cooling mode, valve energized

Auto: the state of the valve depends on the value of the ambient temperature in respect to the set point. The state of the valve is changed, if required, at the moment the actuators are activated.

Parameter H14 can be used to choose the logic of the relay dedicated to the reverse cycle valve. When the unit is switched off or when the set point has been reached, stopping the devices, the valve remains in its existing position, until the next request.

Heater management

When the instrument is configured for 2 or 3 heaters, SEQUENTIAL heater management is used. The heaters are switched on/off in sequence, with a time interval (parameter c8) between the activation of heater 1, always activated first, heater 2, always activated second and heater 3, always activated third. During shut-down heater 3, if activated, is switched off first, then heater 2 and finally heater 1.

Auxiliary heater management

The auxiliary heater is activated, if enabled by parameter R10, when the heat pump system is not able to maintain the desired temperature, such as when the outside temperature is too low. If this is an occasional occurrence, the compressors may be left on; otherwise they are shut-down (selected by parameter R11), still respecting the time delays protection.

Supply fan management

The supply fan may feature from 1- to 3- speed operation. In order to reduce current absorbed during start-up, the activation of the corresponding outputs is never simultaneous, but rather delayed by parameter c8. The button "Fan" selects the fan operating mode (energized whenever at least one actuator is operating or always ON).

To reduce the stream of cool air in the ambient, the supply fan is stopped while defrosting except when the auxiliary heater are set to be energized in such situation; this is performed in order to evacuate the energy provided. Using the MODE button the "only ventilation" mode can be selected ("FAN" script appears in the alphanumeric field), disabling temperature and humidity regulation.

Particularly, depending on the speeds of the fan available and the machine model selected, the symbols '1, 2, 3 and auto' next to the fan symbol, which alternate on pressing the FAN button, have the following meaning:

Only ventilation mode (enabled by the MODE button):

models with fan at single speed:

OFF: the supply fan is off

1: supply fan always on

2, 3, auto: not available

models with supply fan provided with three speed rates (split unit):

OFF: the supply fan is off

1: supply fan always on at speed 1

2: supply fan always on at speed 2

3: supply fan always on at speed 3

auto: not available




Fig. 5.2.6.1

HEAT/COOL/AUTO mode (temperature and humidity control activated):

models with supply fan at single speed:

OFF: not available

1: supply fan always on

2, 3: not available

auto: the supply fan follows the operation of the actuators, switching on and off together with these if set by parameter F5.

In this mode you can also select a delay to start the supply fan after the actuators (parameter F1), to allow the exchanger to reach the proper temperature before being ventilated, and one to stop it (parameter F2, still after the actuators), to remove the energy from the exchangers and optimise the system.

models with supply fan provided with three speed rates (split unit):

OFF: not available

1: supply fan always on at speed 1

2: supply fan always on at speed 2

3: supply fan always on at speed 3

auto: the supply fan follows the operation of the actuators and modulates its speed according to the variation of the ambient temperature from the current set point; below the set point the supply fan either switches off or remains on at the minimum speed, according to parameter F5.

In this mode you can also select a delay to start the supply fan after the actuators (parameter F1), to allow the exchanger to reach the proper temperature before being ventilated, and one to stop it (parameter F2, still after the actuators), to remove the energy from the exchangers and optimise the system.

After a certain operating period of the supply fan, set by parameter F4, the replace supply fan filter message is displayed.

Fan Comfort management

With the parameter F5=2 the fan remains always ON with comfort setpoint and works automatically, that is to say in accordance with the devices, with the night time setpoint and unoccupied setpoint; when Aria is OFF, it is OFF. This is a normal management in some worldwide countries.

Anti-stratification

To avoid the stratification of the air and the consequent risk of having different temperature zones in the same environment, it may be useful to activate the supply fan, after a maximum inactivity time. In fact, if the fan is operating in Auto mode, it must start together with the devices, yet in particularly stable environments, where the temperature varies slowly, the devices may also remain off for an extended period, and as a consequence the fan is not started. The anti-stratification function works based on two parameters: a maximum fan inactivity time, F7, calculated only when the unit is on, and the forced start-up time F8. Setting one of the two parameters to zero automatically disables anti-stratification.

Management of the Fan on the external heat exchanger

By selecting parameter H2(=2), it is possible to use the OP output to control one external fan in heat pump units. The external fan is activated together with the compressors and deactivated after a set time (parameter F6) from the deactivation of the compressors. It is deactivated when defrosting.

The external fan may be managed, as desired, simultaneously with the compressors, or alternatively based on the outside temperature values. The choice depends on parameter F7.

If F7=1, 2 or 3, the external fan is managed on the bases of temperature values on the external heat exchanger that determine its behaviour. In cooling mode, the fan is started together with the compressors for a time equal to F10, after this it starts and stops based on the outside temperature thresholds F8 and F9; when the outside temp. > F9, the fan starts, when the outside temp. < F8, the fan stops.

In heating mode, the external fan stops when the outside temp. > F11, and starts when the outside temp. < F12; the time F10 is not used in heating mode.


The parameter F7 allows selection between:

0=fan starts with the compressors in both cooling and heating;

1=fan starts based on the outside temperature in cooling, starts with the compressors in heating;

2=fan starts based on the outside temperature in heating, starts with the compressors in cooling;

3=fan starts based on the outside temperature in both cooling and heating.



Humidifier management

When the humidity probe is available on the terminal (parameter S1=2) and the “OP” relay is programmed to drive a humidifier (parameter H2=0), this is commanded as described for “reverse” operation (5.2.1.10).

Remote operating mode signal

Setting parameter H2=4, the “OP” relay is driven by Aria to signal the current operating mode to an external device. In such a case, the output will be energized while cooling and de-energized while heating (in any case, the “OP” relay is fitted with double terminals). This indication is more reliable than the status of the reverse cycle valve, as the latter changes during defrosts.

5.3 Zone control version

Zone control is performed using a Carel pCO or pCO² programmable controller placed in the centralized AC unit connected to an “Aria” terminal for each zone through Carel pLAN network.

(All the following references to the pCO are also valid for the pCO², unless otherwise specified). These exchange with each other the parameters, the information required for regulation and other information on the status of the system.

The user interface differs from that on the stand-alone model in some aspects:

1. The CLOCK button no longer has the function of setting of the time, as this is provided by the pCO via pLAN. It still however maintains the function of setting the time bands.
2. The MODE button alternates between the only two operating modes allowed: “AUTO” and “OFF”.
3. The FAN button has no function.

5.3.1 Regulation algorithm

Temperature regulation:

There are two possible modes.

Automatic mode (AUTO): this is normal way.

The essential information for the operation of the system is the operating mode (heating or cooling) that the pCO aims to maintain, according to its algorithm. Until the “Aria” receives this value (the pCO operating set point), it does not perform any type of regulation. This information may also be provided by the digital input ID1 (Heating/Cooling hardware selection), to allow the use of Aria wherever pLAN network is not present. The pCO usually operates with two set points, one for cooling and one for heating. These are the limits within which the set point may vary for each zone, as temperatures outside of the values can not be reached. It is not important for the regulation performed by the “Aria” unit to know how the pCO chooses its operating set point (based on digital input or by evaluating the requests from the various zone); it is important on the other hand for it to know what point it has chosen, as it is based on the difference between the ambient temperature and the pCO set point that the terminal decides whether to modulate or close the dampers. The regulation performed is proportional type with a lateral band. For example, during cooling, when the temperature exceeds the set point + the differential, Aria opens the damper completely; when the temperature is below to the set point, on the other hand, it closes it completely. If the temperature is within the lateral band identified by the differential, the damper is open proportionally in the position shown below by the Set Point based on the excursion time of the dampers (parameter L4).




Fig. 5.3.1

In time-band operation mode, pCO must be provided with the real time clock option (part no. PCOCLKMEM0); the current time is in fact then sent to the zones through the network. The pCO², on the other hand, does not require an optional board.

OFF mode

The damper is totally closed and no regulation is performed.

Humidity regulation

The rate of opening of the damper is decided according to the temperature; the pCO can however decide the percentage of humidity to introduce into the duct according to the values arriving from the individual zones related to the ambient humidity and the required humidity (humidity set point).

5.3.2 Damper management

At start-up the instrument forces the dampers to close completely in the excursion time equal to the one set by parameter L4 + 10%. During normal operation, when temperature regulation is requested the control opens and closes the damper with a minimum variation of 5% from the total excursion time. If the damper is required to close to more than 90% of total closure, the control in this case first closes the damper completely and then returns to the required value. The same is true for opening. These actions, as per the total closing of the damper at instrument start-up, allow the control to precisely calculate the degree of opening of the damper at each moment, even if there is no direct feedback from the damper to the control. Finally, when the control is OFF, it completely closes the damper, once again within the set excursion time +10%.


5.4 Pool environment management

Aria is also ideal for the control of pool environments, where it is important to control the pool water temperature and the humidity and temperature of the surrounding environment. A special configuration has been designed for this purpose, H1=17, where the relay manages the heaters and a pump for the water, and compressors, heaters and fans for the air. The probes are used to measure the water temperature (B3) and the ambient temperature (B1) and humidity (B2).

Optional water heaters can be managed by the optional relay, enabling them by setting parameter H2=3.

The following diagram summarises the management of the devices based on the water temperature and the ambient humidity; these are the two most important measurements.

WARNING: the ambient temperature probe may at any moment activate the ambient heating and cooling devices, so as to maintain the Comfort, Night-time or Unoccupied temperature set point.



1. If: $(Pool\ Set - Pool\ Diff.) < T.pool < Pool\ Set \rightarrow$ activation of ambient air dehumidification (fan, compressors and possibly post heating) and pool heating (the hot gas is sent to the pool's heater). The humidity probe is not considered.
2. If: $T.pool < (Pool\ Set - Pool\ Diff) \rightarrow$ activation of ambient air dehumidification and pool heating with two heaters. The humidity probe is not considered.
3. If: $T.pool > Pool\ Set \rightarrow$ the humidity probe is considered: if dehumidification is not requested, all the devices are deactivated; with high humidity, activation of dehumidification (fan, compressors and possibly post heating).

The priorities are: 1= Ambient air dehumidification; 2=Heating water; 3=Ambient air-conditioning.

The parameters used to manage the water set point and differential are R2 and R14.

PUMP MANAGEMENT

The pump usually operates in accordance with the devices, that is, with the water heaters; if no heater is active, the pump remains off. The pump can also operate in continuous mode, and in this case the choices are: only in Unoccupied mode, or in all operating categories (Comfort, Night-time, Unoccupied). Parameter H18.

For the management of the water flow switch, see paragraph 5.6.

IMPORTANT: given that in environments such as pools, the atmosphere is very aggressive due to the presence of chlorine, Aria should be installed in a protected place or in a separate room, leaving only the probes in the pool environment being controlled. Use Aria terminals fitted for remote probes (codes TAT000R...) and temperature and humidity probes for industrial use or in any case with good atmospheric resistance.

5.5 pLAN connection

Even though connection to a pLAN network is designed mainly for the zone control version, the stand-alone version may also be connected to a Carel pCO local network. Connection is made using the RS-485 standard, with 2 leads and asynchronous half-duplex serial transmission. To overcome the fact that the code for the “Aria” control resides in ROM and thus can not be reconfigured according to the devices which make up the network (as it is normally done for pCO devices), some limits have had to be introduced in respect to normal pLAN network management:

- Aria can receive data from any pCO board, yet can only send data to the pCO board whose network address is set by parameter L2;
- incoming data is identified using the address described in the following tables (RX INDEX ADD);
- outgoing data is written to the physical address (RX INDEX ADD * 2) + (L3*256) of the device with network address set by parameter L2.

The data is only transmitted in the case of variations to the data themselves, except for the parameters with address from 1 to 111 which are only sent on explicit request (var. 156). In order not to overcharge the management of such variations, the remaining variables have been divided into the following groups:

- analogue variables from 138 to 150;
- integer variables from 156 to 170;
- binary variables from 171 to 186.

The variation of one of the variables in the group means the whole group will be sent.

The range of values allowed is indicated in brackets; when there are no numeric indications or references to other parameters, the first identifier has a value of zero, and the successive ones in the list have values in increasing order; example: (OFF, AUTO, SPD1, SPD2, SPD3) means (0, 1, 2, 3, 4). Some data is visible both as variables and as parameters; if accessing a set point as a parameter rather than as a variable, the modification will NOT be accepted, as delayed saving is required, which is only possible when accessing as a variable.

Following is a description of the information which may be exchanged between the “Aria” controller and the pCO or pCO².

5.5.1 List of variables

If the variation field, in the brackets, contains some nouns, they are the meaning of the values 0, 1, 2 ... of the parameter.

For ex. R19 (P, P+I) means 0=P, 1=P+I.

In the parameters where there is only (0÷1) , 0 means NO, while 1 = YES, i.e. enabled or not enabled function.

DIGITAL			
RX INDICES	READ	WRITE	AUX
171	ID1 <i>if enabled</i>	-	YES
172	ID2 <i>if enabled</i>	-	YES
173	ID3 <i>if enabled</i>	-	YES
174	-	alarm reset	
175	-	hardware reset	
176	-	send forced parameters	
177	-	output status set by remote	
178	buzzer status (0=mute; 1=active)	force buzzer	YES
179	control status (0=stand-by; 1=active)	-	YES
180	remote alarm	remote alarm (<i>not activated in OFF</i>)	YES
181	-	ID1 from remote	
182	-	ID2 from remote	
183	-	ID3 from remote	
184	-	manual defrost	
185	-	force ON (<i>simulates the MODE button</i>)	YES
186	alarm status (0=no alarm; 1=alarms present)	-	

ANALOG			
RX INDICES	READ	WRITE	AUX
138	probe B1	-	YES
139	probe B2	-	YES
140	probe B3	-	YES
141	current temperature set point	temperature set point in Manual (without clock)	
142	UNOCCUPIED set point	UNOCCUPIED set point	
143	COMFORT set point	COMFORT set point	
144	NIGHT-TIME set point	NIGHT-TIME set point	
145	temperature differential	temperature differential (R3)	
146	remote set point	remote set point from pCO or pCO2	
147	-	remote probe B1 (if bit 0=1, variable L5)	
148	-	remote probe B2 (if bit 1=1, variable L5)	
149	-	remote probe B3 (if bit 2=1, variable L5)	
150	effective temperature set point R SP	-	

INTEGER			
RX INDICES	READ	WRITE	AUX
156	output status (bit 0=relay 7 or triac no.1 bit 1=relay 6 or triac no.2 bit 2=relay 5 bit 3=relay 4 bit 4=relay 3 bit 5=relay 2 bit 6=relay 1)	-	
157	percentage of damper opening	-	
158	humidity set point	humidity set point (<i>no write if is in parameter modification mode</i>)	
159	local clock HOURS	local clock HOURS	YES
160	local clock MINUTES	local clock MINUTES	YES
161	local clock DAY	local clock DAY	YES
162	manual operating mode (<i>AUTO, COOL, HEAT, FAN-ONLY</i>)	manual operating mode (<i>AUTO, COOL, HEAT, FAN-ONLY</i>)	
163	fan operating mode (<i>OFF, AUTO, SPD1, SPD2, SPD3</i>)	fan operating mode (<i>OFF, AUTO, SPD1, SPD2, SPD3</i>)	
164	Alarm signal 1 (bit0: compressor maintenance alarm 1: HR 1 bit1: compressor maintenance alarm 2: HR 2 bit2: supply fan maintenance alarm: HR F bit3: high temperature alarm: HI T bit4: low temperature alarm: LO T bit5: alarm from digital input: E ID bit6: alarm from pLAN: REM bit7: defrost over maximum time alarm: E DF bit8: EEPROM error at boot: EE bit9: run-time EEPROM error: EE bit10: not used bit11: terminal communication error: E SR bit12: power board communication error: E TR bit13: NTC control probe error: E1 bit14: 0/1Vdc probe error: E2 bit15: power board probe error: E3)	-	
165	Alarm signal 2 (bit 0=pool pump alarm P AL bit 1=fan thermal cut-off alarm Th F bit 2=not used bit 3=not used bit 4=high humidity alarm HI H bit 5=low humidity alarm LO H bit 6=low pressure alarm LO P)	-	
166	machine status flag bit 0=clock present (internal or remote) bit 1=clock operating correctly bit 2=internal clock present bit 3= 0->manual / 1->time bands bit 4=not used bit 5=options present)	-	
167	-	output status for remote control from pCO or pCO2 (the write is significant if enabled by variable 177; each bit corresponds to the status of one output: bit0=relay 7 or triac 1 bit1=relay 6 or triac 2 bit2=relay 5 bit3=relay 4 bit4=relay 3 bit5=relay 2 bit6=relay 1)	YES
168	-	remote probe alarm (the write is significant if enabled by parameter L5 (bit0, bit1, bit2): bit0: probe B1 error bit1: probe B2 error bit2: probe B3 error)	YES
169	set point category (<i>UNOCCUPIED, COMFORT, NIGHT-TIME, STAND-BY</i>)	set point category in manual operation (<i>UNOCCUPIED, COMFORT, NIGHT-TIME, STAND-BY</i>) if in time band mode, the write is enabled if bit 7 of parameter L5 is equal to 1	YES
170	automatic operating modes (<i>AUTO, COOL, HEAT, FAN-ONLY</i>)	-	

PARAMETERS		
RX INDICES	DESCRIPTION	AUX
1	S2 lower extreme of the range of temperature/humidity probe B2 measurements (-150..S3)	
2	S3 upper extreme of the range of temperature/humidity probe B2 measurements (S2..150)	
3	S4 offset to apply to the temperature measurement by probe B1 (-12.0..12.0)	
4	S5 offset to apply to the temperature measurement by probe B2 (-12.0..12.0)	
5	R1 pool set point (R12..R13)	
6	R4 temperature dead zone (0..10.0)	
7	R8 relative set point for support heaters (0..50.0)	
8	R9 differential for support heaters (1.0..22.0)	
9	R12 minimum allowed limit for the temperature set point (0..R13)	
10	R13 maximum allowed limit for the temperature set point (R12..50.0)	
11	R2 pool temperature differential (1.0..10.0)	
12	H17 pump alarm delay (0..600)	
13	C5 compressor hour counter 1 (0..19.9)	
14	C6 compressor hour counter 2 (0..19.9)	
15	C7 compressor hour counter maintenance threshold (0..10.0)	
16	F3 supply fan hour counter (0..19.9)	
17	F4 supply fan hour counter maintenance threshold (0..10.0)	
18	d3 start defrost temperature (-30.0..d4)	
19	d4 end defrost temperature (d3..50.0)	
20	P3 high temperature alarm threshold (P4+1..150)	
21	P4 low temperature alarm threshold (0..P3-1)	
22	S1 type of probe B2 (0, 1, 2) (0=Absent, 1=0/1V temperature, 2=0/1V humidità)	
23	S6 digital filter for input B1 (1..15)	
24	S7 temperature unit of measure (0=°C, 1=°F)	
25	S8 select source for probe B1 (0, 1) (0=internal, 1=external)	
26	R5 humidity set point (R16..R17)	
27	R6 humidity differential (R16..R17)	
28	R7 enable dehumidification (0..1)	
29	R10 enable support heaters (0..1)	
30	R11 enable compressors with support heaters (0..1)	
31	R16 minimum allowed limit for the humidity set point (0..R17)	
32	R17 maximum allowed limit for the humidity set point (R16..100)	
33	R18 enable compressor rotation (NO, NORMAL)	
34	R19 type of control (P, P+I) (0=P, 1=P+I)	
35	R20 integration constant for PI algorithm (20..999)	
36	R21 control delay (0..600)	
37	C1 minimum compressor on time(0..300)	
38	C2 minimum compressor off time (0..900)	
39	C3 minimum time between two starts of the same compressor (0..900)	
40	C4 minimum time between starts of two compressors (0..150)	
41	C8 interval between heaters on / supply fan speed change (0..60)	
42	F1 supply fan start delay (0..10)	
43	F2 supply fan stop delay (0..180)	
44	F5 supply fan always on (0..1)	
45	F6 external fan stop delay (0..180)	
46	d1 enable defrost (0..1)	
47	d2 type of end defrost (0, 1, 2) (0=time, 1=temperature, 2=from ID3)	
48	d5 minimum start defrost time (10..120)	
49	d6 maximum defrost duration (1..900)	
50	d7 delay between two defrost requests (10..180)	
51	d8 support heaters in defrost (0..1)	
52	P1 enable buzzer (0..1)	
53	P2 type of alarm from digital input ID3 (0, 1) (0=signal only, 1=serious alarm)	
54	P5 delay for high/low temperature/humidity alarms (0..120)	
55	H1 machine model (0..19)	
56	H2 function of the programmable output (0, 1, 2, 3, 4, 5) (0= humidifier; 1=alarm; 2=external fan; 3=pool heater; 4=operatine mode signal; 5=Comfort mode signal)	
57	H3 function of digital input ID1 (0, 1, 2, 3) (0=absent; 1=remote cooling/heating selection; 2=alarm filter; 3=fan thermal cut-off alarm with "th F" signal)	
58	H4 function of digital input ID2 (0, 1, 2, 3) (0=absent; 1= remote ON/OFF; 2=water pump alarm with "P AL" signal; 3=low pressare alarm with "LO P" signal)	
59	H5 function of digital input ID3 (0, 1, 2, 3) (0=absent; 1= general alarm; 2=end defrost; 3=remote ON/OFF)	
60	H6 lock keypad (0..1)	
61	H7 select display on LCD (B2, CURRENT SET POINT, B3)	
62	H8 set point override time (0.24)	
63	H9 clock display 12/24 hours (0..1) (0=24h, 1=12h)	
64	H10 LCD contrast (-25..25)	
65	H11 enable button click (0..1)	

66	H12	<i>back-lit front panel buttons at rest (0..1)</i>	
67	H13	<i>enable clock (0, 1, 2) (0=disabled, 1=local, 2=remote)</i>	
68	L1	<i>serial device address (1..31 – 1..207)</i>	
69	L2	<i>pLAN destination address (0..31)</i>	
70	L3	<i>pLAN page (0..255)</i>	
71	L4	<i>dampers stroke time (1..900)</i>	
72	L5	<i>select alarm source (0..255)</i>	
73	SP5	<i>firmware version (0..255)</i>	
74	dev9	<i>machine operating status (0..255)</i>	
75	R28	<i>free-cooling/free-heating differential (0.5..15.0)</i>	
76	R23	<i>K+ for temperature set point compensation (0..10.0)</i>	
77	R24	<i>K- for temperature set point compensation (0..10.0)</i>	
78	C9	<i>compressor hour counter 3 (0..19.9)</i>	
79	C10	<i>compressor hour counter 4 (0..19.9)</i>	
80	P6	<i>delay in alarm from input ID3 (0..600)</i>	
81	H14	<i>select active valve status (0, 1) (0= normal logic, 1=opposite logic)</i>	
82	H15	<i>enable dehumidification in UNOCCUPIED and NIGHT-TIME (0..1)</i>	
83	R25	<i>minimum limit for the entity of set point compensation (-10.0..0)</i>	
84	R26	<i>maximum limit for the entity of set point compensation (0..10.0)</i>	
85	R27	<i>type of free-cooling/free-heating (0, 1, 2, 3, 4, 5, 6, 7) (0=disabled; 1=free-cooling without compressors; 2=free-heating without compressors; 3=free-cooling+free-heating without compressors; 4=disabled; 5=free-cooling with compressors; 6=free-heating with compressors; 7=free-cooling+free-heating with compressors)</i>	
86	P7	<i>low humidity alarm threshold (0..P8)</i>	
87	P8	<i>high humidity alarm threshold (P7..100)</i>	
88	H16	<i>enable set point compensation (0..1)</i>	
89	P9	<i>delay in low pressure alarm on ID2 in normal operation (0..900)</i>	
90	P10	<i>delay in low pressure alarm on ID2 in heating with heat pump (0..900)</i>	
91	P11	<i>delay in low pressure alarm on ID2 in defrost (0..900)</i>	
92	P12	<i>type of reset for low pressure alarm on ID2 (0, 1, 2, 3, 4, 5) (0=automatic ; 1=manual ; 2..5=number of automatic resets within 1 hour from the first alarm, then manual reset)</i>	
93	S9	<i>digital filter for input B2 (1..15)</i>	
94	S10	<i>digital filter for input B3 (1..15)</i>	
95	d9	<i>pause after compressors stop in defrost (0..180)</i>	
96	d10	<i>pause after reversing of the cycle in defrost (0..180)</i>	
97	F10	<i>external pre-ventilation time for condensation control (0..180)</i>	
98	F7	<i>enable condensation control in HEAT and COOL mode (0, 1, 2, 3) (0=disabled; 1=enabled in Cooling; 2=enabled in Heating; 3= always enabled)</i>	
99	F8	<i>external fan stop temperature for condensation control in cooling. (0.0..F9)</i>	
100	F9	<i>external fan start temperature for condensation control in cooling (F8..60.0)</i>	
101	F11	<i>external fan stop temperature for condensation control in heating. (F12..50.0)</i>	
102	F12	<i>external fan start temperature for condensation control in heating. (0.0..F11)</i>	
103	d12	<i>entity of intelligent increase/decrease in interval between defrosts (0..36)</i>	
104	F13	<i>supply fan start delay after compressors ON at end defrost (0..180)</i>	
105	d11	<i>forced defrost temperature (-50.0..50.0)</i>	
106	F14	<i>supply fan inactivity time to activate anti-stratification (0..999)</i>	
107	F15	<i>duration of ventilation for anti-stratification (0..99)</i>	
108	d13	<i>manual defrost (0..1)</i>	
109	H18	<i>pump configuration (ON DEMAND, CONTINUOUS, CONTINUOUS IN COMFORT)</i>	
110	R29	<i>compressor disable differential $T_{AMB} - T_{OUT}$ (0..50.0)</i>	
111	R14	<i>enable anti-freeze (0..1)</i>	

Notes on switching the machine off and on

The unit can be switched OFF and ON from the keypad using the Mode button, by opening digital input (2 or 3) or simulating the opening of the same by pLAN through variable 172 (only if L5=32 and H4=1) or controlling digital input 3 via pLAN with the variable 173 (only if L5=64 and H5=3); in any case “who” turns the unit OFF always has priority over “who” wants it ON again. However, on setting variable 185 by pLAN forces the unit ON, no matter if it was previously turned off by keypad or ID2.

AUX variables

The variables declared to be AUX are stored in RAM and must be initialised by pCO when powering Aria.

5.6 Digital inputs

These are physically located on the power board and need to be enabled via the terminal, by setting the corresponding parameters H3, H4, and H5 (they may derive from pLAN network if enabled by parameter L5).

ID1: Heating/Cooling selection - Filter Alarm – fan thermal cut-off alarm digital input

If H3=0 the input is disabled.

If H3=1 the unit operating mode is forced to be heating or cooling; this has priority over the commands sent by keypad (open contact: Cooling/Summer operations, closed contact: Heating/Winter operations)

If H3=2 it has the function of non-serious alarm input, signalling the need to change the fan filter (open contact: clogged filter alarm, closed contact: no alarm).

If H3=3, digital input ID1 may be used to control the supply fan thermal cut-off alarm; this is an immediate alarm showing Th F blinking, and shuts down all the devices. Manual reset.

Selecting the fan thermal cut-off switch with H3=3 modifies the effect of the general alarm on ID3 if this is used as a serious alarm (H5=1 and P2=1):

With H3=3, H5=1, P2=1 if the alarm on ID3 goes off, all devices are stopped, except the supply fan.

- With H3≠3, H5=1, P2=1 if the alarm on ID3 goes off, all devices are stopped.

ID2: ON/OFF – water pump alarm – low pressure alarm digital input

If H4=0, the input is disabled.

If H4=1 and the contact is detected open, Aria is switched off independently from the keypad commands. If the contact is closed Aria is enabled and operates depending on the keypad commands.

If H4=2, digital input ID2 is used to connect a water flow switch; if, within a certain time (H17) after starting the pump, the flow switch is not yet closed, an alarm is generated, with P AL blinking, and the pool pump and heating functions are deactivated until the alarm is reset, automatically. For further information, see the paragraph on Pool environment management.

If H4=3, digital input ID2 is used to manage the low pressure alarm; this is an alarm with different delay times, according to the operating mode (P9=delay in cooling, P10=delay in PdC, P11=delay in defrost). The effect is to shut-down the compressors and the external fan (if present), and the text LO P blinks on the display. The parameters P10 and P11, if set to 0, disable the alarm in the PdC and/or defrost modes. The alarm may not on the other hand be disabled in Cooling mode, so that if P9=0 the alarm is immediate.

The reset may be automatic, manual or mixed, as desired. The selection is made using parameter P12, which has the following values: 0=always automatic reset; 1=always manual reset; 2..5=number of automatic resets, the following alarm is manual reset. The count of the number of alarms generated refers to a period 1 hour from the first alarm; after this period the count is reset and starts from 0 again. "Mixed" management allows the possibility to restart the unit in the event of an alarm, avoiding service intervention unless strictly necessary.

ID3: General alarm end defrost – Remote On/Off digital input

If H5=0, the input is disabled.

(H5=1) The digital input takes the function of general alarm input. In this case another parameter (P2) determines the response of the control to this alarm; only visualization without any effect on the outputs (P2=0), or a serious alarm that activates the alarm relay and blocks all the outputs (P2=1).

The general alarm is delayed by the time set for P6.

If H5=2, the opening of the contact ends the defrost cycle; for this to occur, parameter d2, end defrost mode, must in any case be equal to 2.

If H5=3, the input is used as a Remote On/Off using the same logic described for input ID2. This function is repeated in two inputs to allow the possibility of using it together with the Low pressure alarm function.

5.7 Supervisor

ARIA can be connected to a supervisor installed on a PC, via RS485 serial line. The Carel communication protocol is used in this case, however, the Carel Gateway also allows connection to Modbus and other protocol systems. The three-lead RS485 line is physically connected using the same connector as the pLAN line, therefore the Aria terminals used must feature the pLAN option (codes TAT...PW0). Parameter L6 is used to select between pLAN or RS485 line. The communication speed may be set between 1200 baud and 9600 baud, using parameter L7.

The following table shows the variables that can be sent and received. How these are used depends on the type: those marked **R** can be read, those marked **W** can be written, and those marked with both symbols can be both modified and read with the same variable.

The range of values allowed is indicated in brackets; when there are no numeric indications or references to other parameters, the first identifier has a value of zero, and the successive ones in the list have values in increasing order; example: (OFF, AUTO, SPD1, SPD2, SPD3) means (0, 1, 2, 3, 4).

Some data is visible both as variables and as parameters; if accessing a set point as a parameter rather than as a variable, the modification will NOT be accepted; therefore for display only use the parameter, to modify it use the variable.

DIGITAL		
VARIABLES	R	W
1	ID1 <i>if enabled</i>	-
2	ID2 <i>if enabled</i>	-
3	ID3 <i>if enabled</i>	-
4	-	reset alarms
5	-	reset hardware
6	-	send forced parameters
7	-	output status set by remote
8	buzzer status (0= <i>mute</i> ; 1= <i>active</i>)	force buzzer
9	control status (0= <i>stand-by</i> ; 1= <i>active</i>)	-
10	remote alarm	remote alarm (<i>not activated in OFF</i>)
11	-	ID1 from remote
12	-	ID2 from remote
13	-	ID3 from remote
14	-	manual defrost
15	-	force ON (<i>simulates the MODE button</i>)
16	alarm status (0= <i>no alarm</i> ; 1= <i>alarms present</i>)	-

ANALOGUE		
VARIABLES	R	W
1	probe B1	-
2	probe B2	-
3	probe B3	-
4	current temperature set point	current temperature set point
5	BRIEFCASE set point	BRIEFCASE set point
6	ARMCHAIR set point	ARMCHAIR set point
7	MOON set point	MOON set point
8	temperature differential	temperature differential
9	remote set point	remote set point
10	-	remote probe B1
11	-	remote probe B2
12	-	remote probe B3
13	effective temperature set point	effective temperature set point
PARAMETERS		
21	R1 <i>pool set point (10.0..38.0)</i>	
22	R5 <i>humidity set point (R16..R17)</i>	
23	R8 <i>relative set point for support heaters (0..50.0)</i>	
24	devB <i>remote temperature set point (R12..R13)</i>	
25	R12 <i>minimum allowed limit for the temperature set point (0..R13)</i>	
26	R13 <i>maximum allowed limit for the temperature set point (R12..50.0)</i>	
27	R16 <i>minimum allowed limit for the humidity set point (0..R17)</i>	
28	R17 <i>maximum allowed limit for the humidity set point (R16..100)</i>	
29	R6 <i>humidity differential (R16..R17)</i>	
30	R9 <i>differential for support heaters (1.0..22.0)</i>	
31	R2 <i>pool temperature differential (1.0..10.0)</i>	
32	R4 <i>temperature dead zone (0..10.0)</i>	
33	C5 <i>compressor hour counter 1 (0..19.9)</i>	
34	C6 <i>compressor hour counter 2 (0..19.9)</i>	
35	C9 <i>compressor hour counter 3 (0..19.9)</i>	
36	C10 <i>compressor hour counter 4 (0..19.9)</i>	
37	F3 <i>supply fan hour counter (0..19.9)</i>	
38	C7 <i>compressor hour counter maintenance threshold (0..10.0)</i>	
39	F4 <i>supply fan hour counter maintenance threshold (0..10.0)</i>	
40	P3 <i>high temperature alarm threshold (P4+1..150)</i>	
41	P4 <i>low temperature alarm threshold (0..P3-1)</i>	
42	P7 <i>low humidity alarm threshold (0..P8)</i>	
43	P8 <i>high humidity alarm threshold (P7..100)</i>	
44	d3 <i>start defrost temperature (-30.0..d4)</i>	

45	d4	end defrost temperature (d3..50.0)
46	d11	forced defrost temperature (-50.0..50.0)
47	F8	external fan stop temperature for condensation control in cooling. (0.0..F9)
48	F9	external fan stop temperature for condensation control in cooling (F8..60.0)
49	F11	external fan stop temperature for condensation control in heating. (F12..50.0)
50	F12	external fan stop temperature for condensation control in heating. (0.0..F11)
51	R28	free-cooling/free-heating differential (0.5..15.0)
52	R29	compressor disable differential $ T_{AMB} - T_{OUT} $ (0..50.0)
53	R23	K+ for temperature set point compensation (0..10.0)
54	R24	K- for temperature set point compensation (0..10.0)
55	R25	minimum limit for the entity of set point compensation (-10.0..0)
56	R26	maximum limit for the entity of set point compensation (0..10.0)
57	S2	lower extreme of the range of temperature/humidity measurements probe B2 (-150..S3)
58	S3	upper extreme of the range of temperature/humidity measurements probe B2 (S2..150)
59	S4	offset to apply to the temperature measurement by probe B1 (-12.0..12.0)
60	S5	offset to apply to the temperature measurement by probe B2 (-12.0..12.0)

INTEGER		
VARIABLES	R	W
1	output status in local or remote control	-
2	percentage of damper opening	-
3	humidity set point	humidity set point (no write if in parameter modification)
4	local clock HOURS	local clock HOURS
5	local clock MINUTES	local clock MINUTES
6	local clock DAY	local clock DAY
7	manual operating mode (<i>AUTO, COOL, HEAT, FAN-ONLY</i>)	manual operating mode (<i>AUTO, COOL, HEAT, FAN-ONLY</i>)
8	fan operating mode (<i>OFF, AUTO, SPD1, SPD2, SPD3</i>)	fan operating mode (<i>OFF, AUTO, SPD1, SPD2, SPD3</i>)
9	alarms 0	-
10	alarms 2	-
11	machine status flag	-
12	-	status outputs for remote control
13	-	remote probe alarm
14	set point category (<i>UNOCCUPIED, COMFORT, NIGHT-TIME, STAND-BY</i>)	set point category in manual operation (<i>UNOCCUPIED, COMFORT, NIGHT-TIME, STAND-BY</i>)
15	automatic operating modes (<i>AUTO, COOL, HEAT, FAN-ONLY</i>)	-
PARAMETERS		
21	S1	type of probe B2 (0, 1, 2) (0=absent, 1=0/1 Vdc temperature, 2=0/1 Vdc humidity)
22	S8	select source for probe B1 (0, 1) (0=internal, 1=external)
23	S6	digital filter for input B1 (1..15)
24	S9	digital filter for input B2 (1..15)
25	S10	digital filter for input B3 (1..15)
26	R19	type of control (P, P+I) (0=P, 1=P+I)
27	R20	integration constant for PI algorithm (20..999)
28	R21	control delay (0..600)
29	H3	function of digital input ID1 (0, 1, 2, 3) (0=absent; 1= remote cooling/heating selection; 2=filter alarm; 3=fan thermal cut-off alarm with "th F" signal)
30	H4	function of digital input ID2 (0, 1, 2, 3) (0=absent; 1= remote ON/OFF; 2=water pump alarm with "P AL" signal; 3=low pressure alarm with "LO P" signal)
31	H5	function of digital input ID3 (0, 1, 2, 3) (0=absent; 1= general alarm; 2=end defrost; 3=remote ON/OFF)
32	P2	type of alarm from digital input ID3 (0, 1) (0=signal only, 1=serious alarm)
33	S7	temperature unit of measure (0=°C, 1=°F)
34	H17	pump alarm delay (0..600)
35	H18	pump configuration (0=ON DEMAND, 1=CONTINUOUS, 2=CONTINUOUS IN COMFORT)
36	c1	minimum compressor on time (0..300)

37	c2	<i>minimum compressor off time (0..900)</i>
38	c3	<i>minimum time between two starts of the same compressor (0..900)</i>
39	c4	<i>minimum time between starts of two compressors (0..150)</i>
40	c8	<i>interval between heaters on / supply fan speed change (0..60)</i>
41	F1	<i>supply fan start delay (0..180)</i>
42	F2	<i>supply fan stop delay (0..180)</i>
43	F6	<i>external fan stop delay (0..180)</i>
44	F10	<i>external pre-ventilation time for condensation control (0..180)</i>
45	F13	<i>supply fan start delay after compressors ON at end defrost (0..180)</i>
46	F14	<i>supply fan inactivity time to activate anti-stratification (0..999)</i>
47	F15	<i>duration of ventilation for anti-stratification (0..99)</i>
48	R18	<i>enable compressor rotation (NO, NORMAL)</i>
49	R10	<i>enable support heaters (0..1)</i>
50	R11	<i>enable compressors with support heaters (0..1)</i>
51	F7	<i>enable condensation control in HEAT and COOL mode (0, 1, 2, 3) (0=disabled; 1=enabled in Cooling; 2=enabled in Heating; 3=always enabled)</i>
52	P5	<i>delay in high/low temperature/humidity alarms (0..120)</i>
53	P9	<i>delay in low pressure alarm on ID2 in normal operation (0..900)</i>
54	P10	<i>delay in low pressure alarm on ID2 in heating with heat pump (0..900)</i>
55	P11	<i>delay in low pressure alarm on ID2 in defrost (0..900)</i>
56	P6	<i>delay in alarm from input ID3 (0..600)</i>
57	H7	<i>select display on LCD (0=B2, 1=CURRENT SET POINT, 2=B3)</i>
58	H9	<i>clock display 12/24 hours (0, 1) (0=24h 1=12h)</i>
59	H13	<i>enable clock (0, 1, 2) (0=disabled; 1=local; 2=remote (from pLAN))</i>
60	H6	<i>lock keypad (0..1)</i>
61	H10	<i>LCD contrast (-25..25)</i>
62	H11	<i>enable button click (0..1)</i>
63	H12	<i>back-lit front panel buttons at rest (0..1)</i>
64	P1	<i>enable buzzer (0..1)</i>
65	dev9	<i>machine operating status (0..255)</i>
66	H8	<i>set point override time (0.24)</i>
67	H1	<i>machine model (0..19)</i>
68	H2	<i>function of the programmable output (0, 1, 2, 3, 4, 5) (0= humidifier; 1=alarm; 2= external fan; 3=pool heater; 4=operatine mode signal; 5=Comfort mode signal)</i>
69	H14	<i>select active valve status (0..1)</i>
70	F5	<i>supply fan always on (0..1)</i>
71	d1	<i>enable defrost (0..1)</i>
72	d2	<i>type of end defrost (0, 1, 2) (0=time, 1=temperature, 2=from ID3)</i>
73	d5	<i>minimum start defrost time (10..120)</i>
74	d6	<i>maximum defrost duration (1..900)</i>
75	d7	<i>delay between two defrost requests (10..180)</i>
76	d8	<i>support heaters in defrost (0..1)</i>
77	d9	<i>pause after stop compressors in defrost (0..180)</i>
78	d10	<i>pause after reversing cycle in defrost (0..180)</i>
79	d12	<i>entity of intelligent increase/decrease in interval between defrosts (0..36)</i>
80	d13	<i>manual defrost (0..1)</i>
81	R7	<i>enable dehumidification (0..1)</i>
82	H15	<i>enable dehumidification in UNOCCUPIED and NIGHT-TIME (0..1)</i>
83	R27	<i>type of free-cooling/free-heating (0, 1, 2, 3, 4, 5, 6, 7) (0=disabled; 1=free-cooling without compressors; 2=free-heating without compressors; 3=free-cooling+free-heating without compressors; 4=disabled; 5=free-cooling with compressors; 6=free-heating with compressors; 7=free-cooling+free-heating with compressors)</i>
84	L4	<i>damper stroke time used by stand-alone and free-cooling/free-heating (1..900)</i>
85	H16	<i>enable set point compensation (0..1)</i>
86	P12	<i>type of low pressure alarm reset on ID2 (0, 1, 2, 3, 4, 5) (0=automatic ; 1=manual ; 2..5=number of automatic resets within 1 hour from the first alarm, then manual reset)</i>
87	L1	<i>serial device address (1..31 – 1..207)</i>
88	L2	<i>pLAN destination address (0..31)</i>
89	L3	<i>pLAN page (0..255)</i>
90	L5	<i>select alarm source (0..255)</i>

91	R14 enable anti-freeze (0..1)
92	SP1 coefficient Kg for calibrating NTC probe B1 (-32768..32767)
93	SP2 coefficient Ko for calibrating NTC probe B1 (-32768..32767)
94	SP3 coefficient Kg for calibrating 0/1 V probe B2 (-32768..32767)
95	SP4 coefficient Ko per calibrating 0/1 V probe B2 (-32768..32767)
96	SP5 firmware version (0..255)
97	SP6 programming key version (0..255)
98	SP7 backup flags (0..255)
99	TCFG test configuration (0..255)

6. ALARMS AND TROUBLESHOOTING

The detection of an alarm brings about:

- the activation of the buzzer, if present and enabled (parameter P1 not equal to 0), depending on the type of alarm
- the display of the alarm code and the letters 'AL', alternating with the display of the temperature
- the de activation of some or all the outputs, depending on the type of alarm
- the activation of the alarm relay, if present (parameter H2=1), depending on the type of alarm (**WARNING:** alarm relay refers only to Stand Alone models)




Fig. 6.1

When more than one alarm is detected at the same time, the display automatically scrolls through the occurred alarms.

6.1 Resetting the alarms.

6.1.1 Muting the buzzer:

pressing the RESUME button for less than 3 seconds, whenever an alarm is detected, mutes the buzzer, while the outputs deactivated by the alarm in question remain de energized. The alarm code continues to be displayed, alternating with the measured temperature value.

6.1.2 Automatic reset:

some alarms are automatically reset when the cause is no longer present, that is, they are deactivated: relevant message on the display, buzzer and alarm relay.

6.1.3 Manual reset:

pressing the RESUME button for more than 3 seconds, if the alarm conditions have been removed, the instrument returns to the normal operation and the alarm relay is de-energized. If, on the other hand, the alarm conditions persist, the alarm situation in progress remains.

6.2 Description of the alarms

Detection is immediate for all alarms except the high and low temperature alarms, which are activated after a period set by parameter P5. When the machine is turned OFF, probe alarms are detected only.

The alarms which can be detected are described in the following table:

CODE	TYPE OF ALARM	EXPLANATION
HR 1	Compressor 1 maintenance alarm	Compressor 1 has exceeded the no. of operating hours specified by parameter c7
HR 2	Compressor 2 maintenance alarm	Compressor 2 has exceeded the no. of operating hours specified by parameter c7
HR F	Supply fan maintenance alarm (filter clean)	The supply fan has exceeded the no. of operating hours specified by parameter F4
HI T	High temperature alarm	The temperature measured by probe B1 has exceeded the value of parameter P3
LO T	Low temperature alarm	The temperature measured by probe B1 has fallen below the value of parameter P4
E ID	Alarm from digital input ID3	Digital input ID3 is open
E FL	Alarm from digital input ID1	Digital input ID1 is open
REM	Alarm from pLAN	General alarm signal from the local network
EE	EEPROM error	Read/write error in non-volatile internal memory
E SR	Terminal communication error	The terminal doesn't receive data from the power board

E ST	Power board communication error	The power board doesn't receive data from the terminal
E1	B1 probe error	Ambient temperature regulation B1 probe error
E2	B2 probe error	Humidity/auxiliary temperature active B2 probe error
E3	B3 probe error	Error in the B3 probe on the power board for defrost management
E DF	Defrost alarm	Defrost time has exceeded the maximum specified by parameter d6
LO H	low ambient humidity alarm	The humidity measured by probe B2 is over the value of parameter P8
HI H	high ambient humidity alarm	The humidity measured by probe B2 is below the value of parameter P7
Th F	supply fan thermal cut-off alarm	Digital input ID1 has signalled a fault in the supply fan
LO P	low pressure alarm	Digital input ID2 has signalled low pressure in the refrigerant fluid
P AL	pool water flow switch alarm	Digital input ID2 has signalled the absence of water flow in the pool

Table. 6.2.1

HR 1 - HR 2: Compressor 1 and 2 maintenance alarm

When the number of operating hours of a compressor exceeds the maintenance threshold set by parameter c7 (default c7=0 and thus this signal is disabled) the maintenance required message HR 1 or HR 2 is visualised. The buzzer and the alarm relay are not energized.

To reset this alarm, the operating hour-counter must be set to zero; enter parameter programming mode DIRECT by pressing the SET and HOLD buttons, display the hour-counter in question (parameter c5 or c6), press once SET button to enter the field and then the front buttons at the same time.

HR F: Supply fan maintenance alarm

When the number of operating hours of the supply fan exceeds the maintenance threshold set by parameter F4 (default F4=0 and thus this signal is disabled) the maintenance required message HR F is visualised. The buzzer and the alarm relay are not energized.

To reset this alarm, the operating hour-counter must be set to zero; enter parameter programming mode by pressing the SET and HOLD buttons, display the hour-counter in question (parameter F3), press one SET button to enter the field and then the front buttons at the same time.

HI T: High temperature alarm

When the temperature measured by probe B1 rises above the value specified by the parameter P3 for a period longer than parameter P5, the buzzer and the high temperature alarm message, HI T, are activated. The alarm relay is not energized.

LO T: Low temperature alarm

When the temperature measured by probe B1 falls below the value specified by parameter P4 for a period longer than parameter P5, the buzzer and the low temperature alarm signal, LO T, are activated. The alarm relay is not energized.

E ID: Alarm from digital input

The unit is able to detect external alarms through digital input ID3. When this is detected as being open, the system waits for the delay time P6, then the buzzer and the alarm message E ID are activated. If parameter P2=0 (non serious alarm), there are no other effects; if P2=1 (serious alarm), the alarm relay is energized and there are two types of reaction: if digital input ID1 is connected to the fan thermal cut-off, E ID switches off the outputs but not the fan, otherwise it switches off the outputs and the fan. When considered to be a non serious alarm (P2=0), Aria resets automatically when the cause is no longer valid. If P2=1 (serious alarm) and, again, the cause that generated the alarm is removed, the RESUME button must be pressed for more than 3 seconds (manual reset).

E FL: Filter alarm

The unit is able to detect a possible filter alarm through digital input ID1 (if H3=2). When this is detected as being open the alarm message E FL (filter alarm) is activated.

The alarm is reset automatically when its cause is removed.

REM: Remote alarm from pLAN

This is used as a general alarm signal coming from the Carel pLAN local network via the address variable 160: the buzzer and the alarm message REM are activated. If parameter P2=0 there are no other effects; if P2=1 (serious alarm), all outputs are de-energized and the alarm relay is activated.

The alarm is reset automatically when its cause is removed, if parameter P2=0. If parameter P2=1 (serious alarm), after the cause that generated the alarm is removed, the RESUME button must be pressed for more than 3 seconds.

EE: EEPROM alarm

Signals a read and/or write error in the non-volatile internal memory (EEPROM), thus highlighting a problem in the storage of the parameters.

If this occurs, try switching the controller off and on again: If the problem persists, please contact the local service.

E SR: Terminal communication error

Signals an error in the serial communication between the terminal and the power board: the terminal does not receive the data. The alarm message E SR is displayed, the buzzer is activated and all outputs are de energized. The LED on the power board blinks 3 times (normally once) in 3 seconds.

The alarm is reset automatically, that is when communication is established again.

If the alarm occurs, check the two-lead serial connection between the terminal and the power board.

E ST: Power board communication error

Signals an error in the serial communication between the terminal and the power board: the power board does not receive the data. The alarm signal E ST is displayed, the buzzer is activated and all outputs are de energized. The LED on the power board blinks twice (normally once) in 3 seconds.

The alarm is reset automatically, that is when communication is established again.

If the alarm occurs, check the two-lead serial connection between the terminal and the power board.

E1: B1 temperature regulation probe error

Signals the malfunctioning of the temperature probe used for temperature regulation (B1). Also check the position of jumper J1 (see paragraph Terminal installation). In the case of an alarm, the controller provides the alarm message E1, the buzzer and the alarm relay are activated and all outputs are de-energized, except for the supply fan. The fan stays on to allow air circulation in public areas.

The alarm is reset automatically, that is when communication is established again.

E2: B2 auxiliary probe error

Signals the malfunctioning of the B2 active probe. Also check the position of jumper J2 (see paragraph 3.1).

In the case of an alarm, the control provides the alarm message E2, the buzzer and the alarm relay are activated and the humidification and dehumidification functions are suspended.

The alarm is reset automatically, that is when the sensor starts working correctly.

E3: B3 probe error on power board

Signals the malfunctioning of the probe B1 on the power board. This alarm is only detected if the defrost function is enabled (parameter d1).

In the case of an alarm, the control provides the alarm message E3 and the buzzer and the alarm relay are activated.

The alarm is reset automatically, that is when the sensor starts working correctly.

E DF: Defrost alarm

If the defrost process ends at the maximum time specified by parameter d6, the alarm signal E DF is activated.

The alarm is reset automatically, that is when the following defrost cycle has been performed correctly. It can also be reset by pressing the RESUME button for more than 3 seconds.

HI H: High humidity alarm

When the humidity measured by probe B2 rises above the value specified by parameter P8 for a time greater than P5, the high humidity alarm signal HI H is activated. The alarm relay and the buzzer are not activated.

LO H: Low humidity alarm

When the humidity measured by probe B2 falls below the value specified by parameter P7 for a time greater than P5, the low humidity alarm signal LO H is activated. The alarm relay and the buzzer are not activated.

Th F: Fan thermal cut-off alarm

When digital input ID1 (with H3=3) is closed, the code Th F appears, the buzzer is activated and all the outputs are switched off. The alarm is manual reset, that is, after the cause of the alarm has been removed. See paragraph 5.6.

LO P: Low pressure alarm

When digital input ID2 (with H4=3) is closed, based on the settings of parameters P9, P10 and P11, that is, based on the unit's operating mode, the system waits a delay time and then the code LO P appears, the buzzer is activated and the compressors and the external fan are stopped. The alarm is manual or automatic reset, depending on parameter P12. See paragraph 5.6.

P AL: Alarm pool water flow switch

When the input ID2 (with H4=2) does not close within the maximum time H17 after starting the pump, the code P AL appears, the buzzer is activated and the pump and the water heaters are switched off. The alarm is manual reset. See paragraph on Pool environment management.

The following table summarizes the effect of the alarms and how to reset them:

Displayed message	Meaning	Reset	C,V,R,H TRIAC	Supply fan	Condens er fan	Buzzer	Alarm relay	NOTES
HR 1 HR 2 HR F	Hour-counters C1,C2, supply fan	when resetting the hour-counter)	-	-	-	OFF	OFF	
HI H LO H	high/low humidity	manual				OFF	OFF	action delayed by P5
HI T LO T	High/low ambient temperature	manual	-	-	-	ON	OFF	delayed by P5
E ID	Generic alarm detected by digital input ID3	automatic manual	- OFF	- OFF(in absence of fan thermal cut-off)	- OFF	ON	OFF ON	if P2=0, delay P6 if P2=1 (serious alarm), delay P6
E FL	Filter alarm detected by digital input ID1	automatic	-	-	-	OFF	OFF	
REM	Alarm from pLAN	automatic manual	- OFF	- OFF	- OFF	ON	OFF ON	if P2=0 if P2=1 (serious alarm)
EE	EEPROM alarm	automatic manual	-	-	-	OFF	OFF	autom. when powering man. when operating
E SR E ST	Communication error	automatic	OFF	OFF	OFF	ON	OFF	
E1	probe B1 faulty or disconnected error	automatic	OFF		OFF	ON	ON	
E2	probe B2 faulty or disconnected error	automatic	humid and dehumid. OFF			ON	ON	
E3	B3 probe faulty or disconnected error	automatic		-	OFF	ON	ON	
E DF	Defrost cycle over maximum time	automatic(correct defrost performed) or by pressing RESUME button	-	-	-	OFF	OFF	
Th F	supply fan thermal cut-off alarm	manual	OFF	OFF	OFF	ON	OFF	
LO P	low pressure alarm	automatic or manual	compress. OFF	-	OFF	ON	OFF	action delayed by P9, P10, P11
P AL	pool water flow switch alarm	manual	pump and water heat OFF	-	-	ON	OFF	action delayed by H17

Tab. 6.2.2

Key					
symbol	C	H	R	V	-
meaning	compressors	humidifier	heaters	reverse-cycle valve	No action

7. PROGRAMMING

See **Programming the parameters** for how to access the parameters.

7.1 List of parameters

The table below gives the following information for each parameter:

- the code which appears on the display (COD)
- the type (D, U or F), see **Programming the parameters**
- the operating range (MIN, MAX)
- the unit of measurement used (UNIT):
°C= degrees Centigrade, °F= degrees Fahrenheit, s= seconds, min=minutes, h=hours, Khrs=thousands of hours, %rH=relative humidity;
- the minimum variation allowed (VAR)
- the default value (DEF)
- a brief description (MEANING)
- the visibility of the parameter (VISIBILITY)

The visibility of the parameter determines if a parameter is visible during the programming mode; this may depend on the values of other parameters or on the configuration of the machine; specifically:

C: indicates machines with at least 1 compressor

C2: indicates machines with 2 compressors

F2: indicates machines with at least two-speed supply fans

V: indicates machines with reversing cycle valve (heat pump)

CLK: indicates machines with real time clock

OPT: indicates machines fitted with back-lit LCD, buzzer and B2 probe

7.1.1 Table of parameters

For a more detailed description of the meanings see **Description of the parameters**

parameter	code	type	min	max	unit	var	def	meaning	visibility
S PROBES									
type of second probe (B2)	S1	F	0	2	/	1	0	0=absent, 1=0/1Vdc temperature, 2=0/1Vdc humidity	
min value of second probe (B2)	S2	F	-150 -238 -150	S3	°C °F %rH	0.5 1 1	0.0 32 0	temperature / humidity value corresponding to 0Vdc	S1>0
max value of second probe (B2)	S3	F	S2	150 302 150	°C °F %rH	0.5 1 1	100 212 100	temperature / humidity value corresponding to 1Vdc	S1>0
calibration control probe B1	S4	U	-12.0 10	12.0 54	°C °F	0.5 1	0.0 32	constant value to add / subtract to/from the value measured by the temperature control probe	
calibration probe B2	S5	U	-12.0 10 -12.0	12.0 54 12.0	°C °F %rH	0.5 1 0.5	0.0 32 0.0	constant value to add / subtract to/from the value measured by probe B2	S1>0
digital filter for input B1	S6	U	1	15	/	1	4	filter for analogue input (stabilisation of the measurement)	
temperature unit of measure	S7	U	0	1	/	1	0	0=°C, 1=°F	
internal or external Carel NTC temperature probe B1	S8	U	0	1	/	1	0	0=internal, 1=external	
digital filter for input B2	S9	U	1	15	/	1	4	filter for analogue input (stabilisation of the measurement)	
digital filter for input B3	S10	U	1	15	/	1	4	filter for analogue input (stabilisation of the measurement)	
R CONTROL									
pool temperature Set Point	R1	D	10.0 50	38.0 100	°C °F	0.5 1	28.0 82	the value that the control of the water temperature is based on	
pool temperature differential	R2	D	1.0 34	10.0 50	°C °F	0.5 1	3.0 37		
temperature differential	R3	D	1.0 34	10.0 50	°C °F	0.5 1	3.0 37		
temperature dead zone	R4	D	0.0 32	10.0 50	°C °F	0.5 1	0.0 32		
Humidity set point	R5	D	R16	R17	%rH	1	50	the current value that humidity control is based on	S1=2
humidity differential	R6	D	2	20	%rH	1	5		S1=2
enable dehumidification	R7	U	0	1	/	1	0	0=NO; 1=YES	S1=2
relative Set Point for support heaters	R8	D	0.0 32	50.0 90	°C °F	0.5 1	6.0 43	relates to the current Set Point	V
support heater differential	R9	D	1.0 34	22.0 39	°C °F	0.5 1	3.0 37		V
support heaters present	R10	U	0	1	/	1	0	0=NO; 1=YES	V
compressors with support heaters	R11	U	0	1	/	1	1	0=NO; 1=YES	V
minimum limit for temperature Set Point	R12	U	0.0 32	R13	°C °F	0.5 1	0.0 32		
maximum limit for temperature Set Point	R13	U	R12	50.0 122	°C °F	0.5 1	50.0 122		
enable anti-freeze	R14	U	0	1	/	1	1	start devices if T _{AMB} < P4	
not used	R15								H1=17
minimum limit for Humidity set point	R16	U	0	R17	%rH	1	0		S1=2

parameter	code	type	min	max	unit	var	def	meaning	visibility
maximum limit for Humidity set point	R17	U	R16	100	%rH	1	100		S1=2
compressor rotation	R18	F	0	2	/	1	1	0=disabled; 1=enabled; 2=not used (envisaged for 2 circuits) °	C>1
type of control	R19	U	0	1	/	1	0	0=proportional, 1=proportional+integral	H1 != 15
integration constant	R20	U	20	999	s	1	600		
control delay	R21	U	0	600	s	1	0	delay in the activation of the control on start-up	
positive slope set point compensation	R23	U	0	10.0	/	0.5	2.0	K+ (0=disabled; optimum value=2)	
negative slope set point compensation	R24	U	0	10.0	/	0.5	4.0	K- (0=disabled; optimum value=4)	
lower delta T. for compensated set point	R25	U	-10.0 14	0.0 32	°C °F	0.5 1	-3.0 27	maximum value to decrease the Set Point by for compensation	
upper delta T. for compensated set point	R26	U	0.0 32	10.0 50	°C °F	0.5 1	3.0 37	maximum value to increase the Set Point by for compensation	
select free-cooling and free-heating	R27	F	0	7	/	1	0	0=disabled; 1=free-cooling without compressors; 2=free-heating without compressors; 3=free-cooling+free-heating without compressors; 4=disabled; 5=free-cooling with compressors; 6=free-heating with compressors; 7=free-cooling+free-heating with compressors	
free-cooling differential	R28	U	0.5 33	15.0 59	°C °F	0.5 1	3.0 37	minimum difference between the outside T and ambient T to open the damper	
disable compressor differential	R29	U	0.0 32	50.0 122	°C °F	0.5 1	10.0 50	difference between T _{AMB} and T _{OUT} at which the compressors are disabled (anti liquid hammer); re-enabled when the difference is less than or equal to R29 - 2 °C; 0 = function disabled.	
e COMPRESSORS/HEATERS									
minimum on time	c1	U	0	300	s	1	60		C
minimum off time	c2	U	0	900	s	1	180		C
minimum delay between 2 starts of same compressor	c3	U	0	900	s	1	360		C
minimum delay between starts of the two compressors	c4	U	0	150	s	1	60		C2
hour counter compressor 1	c5	D	0	19.9	kh	/	0	resolution = 0.5 hours	C>0
hour counter compressor 2	c6	D	0	19.9	kh	/	0	resolution = 0.5 hours	C>1
compressor operating hours maintenance threshold	c7	U	0	10.0	kh	0.1	0	no. operating hours beyond which maintenance is requested; 0=function disabled	C
delay between heaters on / speed of supply fan	c8	U	0	60	s	1	10	interval between switching on heater 1, heater 2 and heater 3 and between speed 1, speed 2, speed 3 of the supply fan (split)	R2 or F2
F FANS									
supply fan start delay	F1	U	0	180	s	1	3	delay between activation of actuators and supply fan	H1 != 15,16
supply fan stop delay	F2	U	0	180	s	1	15	delay between deactivation of actuators and supply fan	H1 != 15,16
hour counter supply fan	F3	D	0	19.9	kh	/	0	resolution = 0.5 hours	H1 != 15,16
supply fan operating hours maintenance threshold	F4	U	0	10.0	kh	0.1	0	no. operating hours beyond which maintenance is requested; 0=function disabled	H1 != 15,16
supply fan always on	F5	U	0	2	/	1	0	0=function disabled, 1=supply fan active even when the actuators are off, 2=comfort management	H1 != 15,16
external fan stop delay	F6	U	0	180	s	1	10	delay between deactivation of actuators and external fan	H1 != 15, 16, H2=2
enable condensation function	F7	U	0	3	-	1	0	(0=disabled; 1=enabled in Cooling; 2=enabled in Heating; 3=always enabled)	
external fan off temp. in cooling	F8	U	0.0 32	F9	°C °F	0.5 1	30 86	cooling condensation: external fan stop threshold	F7>0
external fan restart temp. in cooling	F9	U	F8	60.0 140	°C °F	0.5 1	45 113	cooling condensation: external fan start threshold	F7>0
duration of external pre-ventilation	F10	U	0	180	s	1	10	cooling condensation: pre-ventilation	F7>0
external fan off temp. in PdC	F11	U	F12	50.0 122	°C °F	0.5 1	15 59	heating condensation: external fan stop threshold	F7>0
external fan restart temp. in PdC	F12	U	0.0 32	F11	°C °F	0.5 1	12 54	heating condensation: external fan start threshold	F7>0
supply fan delay after defrost	F13	U	0	180	s	1	0	defrosts without support heaters: delay in activation of supply fan after end defrost	d1=1
anti-stratification inactivity time	F14	U	0	999	min	1	0	supply fan inactivity time beyond which the anti-stratification procedure is activated	
anti-stratification duration	F15	U	0	99	min	1	0	duration of ventilation for anti-stratification	
d DEFROST									
perform defrosts	d1	U	0	1	/	1	0	0=disabled; 1=enabled	V
type of end defrost	d2	U	0	2	/	1	0	0=time, 1=temperature, 2=from external contact (ID3)	V, d1=1
start defrost temperature	d3	U	-30.0 -22	d4	°C °F	0.5 1	-5.0 23		V, d1=1
end defrost temperature	d4	U	d3	5.0 41	°C °F	0.5 1	20.0 68		V, d1=1
start defrost delay	d5	U	10	120	s	1	10		V, d1=1
maximum defrost duration	d6	U	1	900	s	1	300		V, d1=1
delay between 2 defrost requests	d7	U	10	180	min	1	10	calculated between the end of one cycle and the start of the next	V, d1=1
support heaters in defrost	d8	U	0	1	/	1	0	0=NO ; 1=YES	V, d1=1
stop comp. before and after defrost	d9	U	0	180	s	1	10	d9 = 0 or d10 = 0 → function disabled	V, d1=1
Comp. start delay after valve switching	d10	U	0	180	s	1	60	d9 = 0 or d10 = 0 → function disabled	V, d1=1
forced defrost temperature	d11	U	-50.0 -58	50.0 122	°C °F	0.5 1	-10.0 14	if T _{OUTSIDE} <= d11 a defrost is performed even if d7 has not elapsed	V, d1=1
variation of "d7" for intelligent defrost	d12	U	0	36	min	1	2	intelligent defrost: variation of the interval between defrosts (0=disabled)	V, d1=1
manual defrost	d13	F	0	1	/	1	0	1=force defrost, after the which the parameter is set to zero	V, d1=1
P ALARMS									
enable buzzer	P1	U	0	15	min	1	1	0=disabled; 1..14=active for 1..14 min; 15=always active	OPT
type of alarm from digital input ID3	P2	U	0	1	/	1	0	0=signal only, 1=serious alarm	
high temperature alarm threshold	P3	U	P4+1 P4+2	150 302	°C °F	0.5 1	40.0 104		
low temperature alarm threshold	P4	U	0 32	P3-1 P3-2	°C °F	0.5 1	10.0 50		
delay in high and low temp. / humid. alarm	P5	U	0	120	min	1	10		
delay in alarm from input ID3	P6	U	0	600	s	1	5	delay in the activation of the alarm after the opening of ID3	
parameter	code	type	min	max	unit	var	def	meaning	visibility

low humidity alarm threshold	P7	U	0	P8	%rH	1	30	"LO H" signal	S1=2
high humidity alarm threshold	P8	U	P7	100	%rH	1	80	"HI H" signal	S1=2
delay low P alarm on ID2 in Cooling	P9	U	0	900	s	1	360		
delay low P alarm on ID2 in PdC	P10	U	0	900	s	1	360		
delay low P alarm on ID2 in defrost	P11	U	0	900	s	1	360		
type of reset low P alarm on ID2	P12	U	0	5	/	1	1	0=automatic; 1=manual; 2..5=number of automatic resets within 1 hour from the first alarm, then manual reset	
H OTHERS									
machine model	H1	F	0	19	/	1	9		
programmable output	H2	F	0	5	/	1	2	0=humidifier control; 1=Alarm; 2=external fan control; 3=pool heater; 4=operating mode signal (heating/cooling); 5=COMFORT mode signal;	H1 != 15,16
function of digital input ID1	H3	U	0	3	/	1	0	0=absent; 1=remote cooling/heating selection; 2=alarm filter; 3=fan thermal cut-off alarm with "th F" signal	
function of digital input ID2	H4	U	0	3	/	1	0	0=absent; 1=Remote ON/OFF; 2=water pump alarm with "P AL" signal; 3=low pressure alarm with "LO P" signal.	
function of digital input ID3	H5	U	0	3	/	1	0	0=absent; 1=general alarm; 2=end defrost; 3=Remote ON/OFF	
lock keypad	H6	U	0	2	/	1	0	0=disabled; 1=enabled	
select display on LCD	H7	U	0	2	/	1	1	0=probe B2; 1=current Set point ; 2=probe B3 on power board	
Set Point override time	H8	U	0	24	h	1	3	Set Point override time. 0=disabled	CLK, H1=15, H1=16
time format:12-24 hours	H9	D	0	1	/	1	0	0=24 hours; 1=12 hours	CLK, H1=15, H1=16
LCD contrast	H10	U	-25	25	/	1	0		
enable button click	H11	D	0	1	/	1	1	0=disabled; 1=enabled	OPT
back-lit front panel buttons at rest	H12	D	0	1	/	1	1	0=OFF, 1=lit at 50%	OPT
enable clock	H13	U	0	2	/	1	1	0=disabled; 1=local; 2=remote (from pLAN)	
reverse cycle valve logic	H14	U	0	1	/	1	0	0=valve active with relay energised; 1=opposite logic	V
enable dehumidify function in unoccupied or night-time mode	H15	U	0	1	/	1	1	0=dehumidification disabled for unoccupied or night-time modes; 1=normal operation	S1=2
enable set point compensation	H16	U	0	1	/	1	0	1=set point compensation enabled	
delay in pump alarm from input ID2	H17	U	0	600	s	1	10	delay in accepting the opening of ID2	
pump operation configuration	H18	U	0	2	/	1	0	0=On Demand; 1=Continuous in all modes; 2=Continuous in Comfort & On Demand in the other modes	
L pLAN									
pLAN serial address	L1	U	1	31 207	/	1	2	address of pLAN / Aria controller supervisor	
pLAN destination address	L2	U	0	31	/	1	1	address of the device the variables are sent to (0=send disabled)	
pLAN page	L3	U	0	255	/	1	181	page of 256 bytes for writing variables to the pCO or pCO ²	
damper stroke time	L4	U	1	900	s	1	60	damper opening or closing time, used both for stand-alone and per free-cooling/free-heating	
select source	L5	U	0	255	/	1	0	bit 0,1,2,3,4,5,6,7: B1,B2,B3,NU,ID1,ID2,ID3,Set Point category; val: 0=local; 1=from pLAN	
type of protocol	L6	U	0	6	/	1	0	0=no protocol; 1=supervisor protocol; 2=pLAN protocol; 3=no protocol; 4=no protocol no I/O board; 5= supervisor protocol no I/O board; 6=pLAN protocol no I/O board	
supervisor protocol baud rate	L7	U	0	3	/	1	3	0=1200 baud; 1=2400 baud; 2=4800 baud; 3=9600 baud	

key				
symbol	>	<	!=	,
meaning	greater than...	less than...	not equal to...	oppure

7.2 Description of the parameters

7.2.1 Probe set-up ("S" parameters)

S1: B2 probe type

Indicates the type of probe connected to terminals B2, AVss of the terminal. There may be no probe (S1=0), an active probe with 0/1Vdc output for measuring the temperature (S1=1), or for controlling humidity (S2=2). Depending on the type selected, the corresponding value of the measurement will be shown in the top right of the display, if enabled by parameter H7.

S2: Minimum value B2 probe

Sets the temperature or humidity value corresponding to a voltage of 0Vdc of B2 probe.

S3: Maximum value B2 probe

Sets the temperature or humidity value corresponding to a voltage of 1Vdc of B2 probe.

S4: Calibration B1 regulation probe

Allows the correction of the value measured by B1 probe, for measuring the ambient temperature.

S5: Calibration, B2 probe

Allows the correction of the value measured by B2 probe.

S6: Digital input filter, probe B1

Allows the setting of the coefficient used in the digital filtering of the value measured and the maximum variation which can be measured by the probes on the terminal in a regulation program cycle. High values for this parameter allow the elimination of any noise in the analogue inputs, yet diminish the reaction time of measurement.

S7: Unit of measure for the temperature

Allows the unit of measure for the temperature to be selected, either in degrees Centigrade (S7=0), or degrees Fahrenheit (S7=1). Once selected, all data is displayed in the chosen unit of measure and the already set values will be converted.

S8: Remoting B1 probe

Informs the control of the presence of the outside temperature probe connected to terminals B1, AVss.

WARNING: to use the external probe for regulation, set jumper J1 on the terminal to position 1-2.

S9: Digital input filter, probe B2

Sets the coefficient used in the digital filtering of the value measured and the maximum variation which can be measured by the probes on the terminal in a regulation program cycle. High values for this parameter allow the elimination of any noise at the analogue inputs, yet diminish the reaction time of the measurement.

S10: Digital input filter, probe B3

Sets the coefficient used in the digital filtering of the value measured and the maximum variation which can be measured by the probes on the terminal in a regulation program cycle. High values for this parameter allow the elimination of any noise at the analogue inputs, yet diminish the reaction time of the measurement.

7.2.2 Regulation set-up (“R” parameters)**R1: Pool water temperature set point**

Allows the current temperature set point to be set to control the temperature of the pool water (with H1=17). The minimum variation is of 0.5°C or 1°F (according to S7 parameter).

R2: Pool water temperature differential

Allows the differential to be set to control the temperature of the pool water (with H1=17). The minimum variation is 0.5°C or 1°F (depending on parameter S7).

R3: Differential

Allows the temperature differential to be set to control temperature (see chapter no.5). The minimum variation is of 0.5°C or 1°F (according to S7 parameter).

R4: Neutral zone

Allows the temperature neutral zone to be set to control temperature (see chapter no. 5). The minimum variation is of 0.5°C or 1°F (according to S7 parameter).

R5: Humidity set point

Allows the current humidity set point to be set to control humidity.

R6: Humidity differential

Allows the humidity differential to be set for humidity regulation (see chapter no. 5).

R7: Enable dehumidification

If set at “1” it enables the process of dehumidification.

R8: Auxiliary heater relative set point

Allows the set point for the auxiliary heaters, as an offset to be subtracted from the main set point (parameter R1) less the possible neutral zone (parameter R4), to be set. The minimum variation is of 0.5°C or 1°F (according to S7 parameter).

R9: Auxiliary heater differential

Allows the differential for the control of the auxiliary heaters to be set. Identifies a lateral band to the auxiliary heater relative set point. The minimum variation is of 0.5°C or 1°F (according to S7 parameter).

R10: Enable auxiliary heaters

If set at “1”, it enables the auxiliary heaters management.

R11: Compressors with auxiliary heaters

Establishes that when the auxiliary heaters are started the compressors must switch off (R11=0), or stay on (R11=1).

R12: Min. temperature set point

Establishes the set point minimum limit for temperature control.

R13: Max. temperature set point

Establishes the set point maximum limit for temperature control.

R14: Anti-freeze

Enables the anti-freeze function, described in paragraph 4.2.4.1.

R16: Min. humidity set point

Establishes the set point minimum limit for humidity regulation.

R17: Max. humidity set point

Establishes the set point maximum limit for humidity regulation.

R18: Compressor rotation

If set at "1", it enables compressor rotation to equalize the operating hours. (see the paragraph on *Output management*).

R19: Type of regulation

Establishes the type of regulation used to control temperature. If R19=0 the control performs proportional regulation; if R19=1 the regulation is proportional plus integral. Humidity control is performed with proportional regulation only.

R20: Integral time constant

Establishes, in the case of integral regulation P+I (R19=1), the integral time constant.

R21: Regulation delay

Establishes the delay to perform any regulation after powering the controller, in order to avoid peaks in current absorption where a large number of "Aria" units is used.

R23: Positive compensation slope (cooling)

This coefficient establishes the exact value by which the set point increases, for each extra degree in the outside temperature. The value is calculated as follows: $(T_{\text{outside}} - \text{Original Set} - R3 - 4^{\circ}\text{C}) / R23$. If $T_{\text{outside}} < (\text{Original Set} + R3 + 4^{\circ}\text{C})$ there is no compensation; when R23=0 there is also no compensation.

R24: Negative compensation slope(heating)

This coefficient establishes the exact value by which the set point decreases, for each degree less in the outside temperature. The value is calculated as follows: $[(\text{Original Set} - R3 - 4^{\circ}\text{C}) - T_{\text{outside}}] / R24$. If $T_{\text{outside}} > (\text{Original Set} - R3 - 4^{\circ}\text{C})$ there is no compensation. When R24=0 there is also no compensation.

R25: Maximum value to decrease set point by for compensation

Maximum value that the set point can be decreased by due to the compensation. When reaching this maximum decrease value, the compensation function no longer has effect.

R26: Maximum value to increase set point by for compensation

Maximum value that the set point can be increased by due to the compensation. When reaching this maximum increase value, the compensation function no longer has effect.

R27: Enable Free-cooling and Free-heating

This parameter is used to enable the Free-cooling and Free-heating functions individually or together.

R28: Differential for Free-cooling – Free-heating activation

This is the minimum allowed difference between the inside and outside temperature for the Free-cooling or Free-heating functions to be activated. Free-cooling can be enabled when the following is true: $\text{Outside Temp.} < (\text{Inside Temp.} - R28)$; Free-heating, on the other hand, can be enabled when: $\text{Outside Temp.} > (\text{Inside Temp.} + R28)$.

R29: Differential for Free-cooling – Free-heating deactivation

This is the maximum allowed difference between the inside and outside temperature for the Free-cooling or Free-heating functions to be activated. Free-cooling can be enabled when the following is true: $\text{Outside Temp.} > (\text{Inside Temp.} - R29)$; Free-heating, on the other hand, can be enabled when: $\text{Outside Temp.} < (\text{Inside Temp.} + R29)$.

7.2.3 Compressor and heater activity ("c" parameters)**c1: Minimum running time**

Sets the time which the compressor must remain ON after start-up, even if it is not effectively requested.

c2: Minimum off time

Sets the time which the compressor must remain OFF after being switched off, even if its start-up is effectively requested. During this phase the ice or flame symbols (on the heat pump model) flash.

c3: Minimum time between two start-ups of the same compressor

Sets the minimum time which must elapse between two successive start-ups of the same compressor. If this time interval occurs, during this phase the ice or flame symbols (on the heat pump model) flash.

c4: Minimum time between the start-up of the two compressors

Establishes the start-up delay between the two compressors, in order to reduce current absorption in case there is a simultaneous request.

c5: Hour-counter compressor 1.

Indicates the number of operating hours of compressor 1. During the display of the operating hours the simultaneous pressing of the front buttons soon after having pressed the SET button, resets the counter and thus cancels the request for maintenance (HR 1 alarm). The unit of measure used for the display is in thousands of hours while the counter resolution is 0.5 hours.

c6: Hour-counter compressor 2

Indicates the number of operating hours of compressor 2. During the display of the operating hours the simultaneous pressing of the front buttons soon after having pressed the SET button, resets the counter and thus cancels the request for maintenance (HR 2 alarm). The unit of measure used for the display is in thousands of hours, while the counter resolution is 0.5 hours.

c7: Compressor operating hours threshold

Establishes the number of compressor operating hours beyond which the maintenance intervention messages, HR 1 and HR 2, are activated. The value c7=0 disables this function. The unit of measure is thousands of hours.

c8: Delay between heaters activation and between supply fan speed variation

Establishes the delay between the activation of the heaters in case there is a full load start up (to reduce starting currents). Such period represents also the delay of activation of the three speeds of the supply fan.

7.2.4 Fans (“F” parameters)**F1: Supply fan start-up delay**

Establishes the delay between the activation of the actuators and that of the supply fan, to allow the coils to reach the proper temperature before letting the air circulate across.

F2: Supply fan shut-down delay

Establishes the delay between the deactivation of the actuators and that of the supply fan, in order to remove the remaining heat in the coils.




F3: Hour-counter supply fan

Indicates the number of fan operating hours. During the display of the operating hours the simultaneous pressing of the front buttons soon after having pressed the SET button resets the counter and thus cancels the request for maintenance (alarm HR F). The unit of measure used for the display is in thousands of hours, while the counter resolution is 0.5 hours.

F4: Supply fan operating hours threshold

Establishes the number of fan operating hours beyond which the maintenance intervention message (HR F) is activated. The value F4=0 disables this function.

F5: Supply fan operating with actuators deactivated

With F5=0, the supply fan follows the functioning of the actuators (apart from the delays set using parameters F1 and F2). With F5=1, the fan remains on also when the actuators are deactivated. With F5=2, the supply fan follows the behaviour of the actuators with night time setpoint  or unoccupied setpoint , whereas it is always ON with Comfrot setpoint .

F6: External fan shut-down delay

Establishes the delay between the deactivation of the compressors and the fan on the condensing coil.

F7: Operation of the external fan

Depending on the setting of F7, the external fan may operate in the following modes: F7=0 together with the compressors; F7=1 together with the compressors in heating, based on the external heater temp. in cooling; F7=2 together with the compressors in cooling, based on the outside temp. in heating; F7=3 always based on the external heater temperature.

F8: External fan stop temperature in Cooling

Valid when F7=1 or 3. This is the temperature value on the external heater below which the external fan is stopped.

F9: External fan start temperature in Cooling

Valid when F7=1 or 3. This is the temperature value on the external heater above which the external fan is started.

F10: Minimum external fan On time in Cooling

Valid when F7=1 or 3. In cooling, when the compressors start, the external fan remains on for the time set by F10 even if the external heater temperature is less than F9; once the time F10 has elapsed, the fan must respect parameters F8 and F9.

F11: External fan stop temperature in Heating

Valid when F7=2 or 3. This is the temperature value on the external heater above which the external fan is stopped.

F12: External fan start temperature in Heating

Valid when F7=2 or 3. This is the temperature value on the external heater below which the external fan is started.

F13: Fan delay after defrosts

If the defrosts do not feature the use of support heaters (d8=0), or alternatively the unit is not fitted with support heaters, the supply fan remains off during defrosts. At the end of the defrosts, when the compressors are started again to satisfy the ambient heating request, the starting of the fan should be delayed, by the time F13, to avoid sending cold air into the room.

F14: Forced fan activation delay

To prevent the supply fan from remaining off for a long time in very stable environment, the time set by F14 is considered the maximum acceptable inactivity time, after which the fan is activated for the time set by F15. The inactivity time F14 is not counted when the machine is off.

F15: Forced fan activation time

When the time F14 has elapsed with the machine on and the supply fan off, the fan is activated for the time set by F15 even if not requested by the system. If the unit is switched off during this function, the action is cancelled.

7.2.5 Defrost (“d” parameters)**d1: Defrost execution**

Establishes if the defrost control of the external heat exchanger, in the case of a heat pump unit, must be performed. If d1=0, the control is disabled. If d1=1, control is enabled and is performed according to the measurement of probe B3 on the relay power board.

d2: Type of defrost termination

Establishes if the defrost termination is based on time (d2=0), or by temperature threshold (d2=1), or when the defrost termination contact, represented by the digital input ID3, is detected open (d2=2). Thus, if d2=0, the duration of the defrost is fixed and is set by parameter d6. If d2=1, the defrost ends when probe B3 on the external heat exchanger reaches the end defrost threshold (d4, if such a value is not reached within parameter d6, defrost is however terminated and the message E DF is displayed). If (d2=2) the defrost ends when the ID3 digital input opens (if this does not occur within parameter d6, defrost is however terminated and the message E DF is displayed).

d3: Start-defrost temperature

Establishes the temperature below which the defrost cycle begins.

d4: Temperature to terminate defrost

Establishes the temperature above which the defrost cycle ends.

d5: Minimum time to start-defrost

Establishes the time which the temperature on the external heat exchanger must remain below the start defrost threshold d3, with the compressor remaining on, to allow the defrost cycle activation.

Such interval is re calculated every time the temperature rises again above the start threshold d3.

d6: Maximum defrost duration

When timed defrost termination is enabled (d2=0), this establishes the duration of the defrost cycle; if on the other hand defrost ends according to temperature or digital contact, it represents the maximum duration; in this case, acting as a safety feature, the alarm message E DF will be displayed.

d7: Delay between two defrost requests

Represents the minimum delay between the end of a defrost cycle and the start of the next one.

d8: Auxiliary heaters during defrost

If set to 1, of the auxiliary heaters will be starting while defrosting to limit the fall in temperature of the supply air. At the same time the supply fan is activated to remove the heat produced.

d9: Compressor stop time before and after defrosts

Both at the start and the end of each defrost, the compressors can be stopped for the time set by d9, so as to allow the fluids in the refrigerating circuit to stabilise before the valve reverses its status. If one of the times d9 or d10 is set to 0, the compressors remain on for the entire defrost process and the valve is reversed with the compressors on.

d10: Compressor start delay after reversing valve switching in defrosts

After the status of the valve has been reversed at the start and the end of the defrosts, the compressors start when the time set by d10 has elapsed. This is true only if a time has been set for d9; if one of the times d9 or d10 is set to 0, the compressors remain on for the entire defrost process and the valve is reversed with the compressors on.

d11: Forced defrost temperature

This is the temperature value of the external condenser, lower than the normal start defrost temperature (d3), at which a defrost is performed without respecting the normal waiting time between two defrosts (d7). The forced defrost can be performed just once; after this, the time d7 must elapse even if the outside temperature is still low.

d12: Intelligent defrost time delta

This is the value in minutes that is subtracted from or added to the time between defrosts, d7, whenever the necessary conditions are true (see par. 5.2.4.5).

d13: Manual defrost

By setting the value of this parameter to 1, the machine performs an immediate defrost; at the end of the defrost, the parameter automatically returns to 0. It is also possible to stop the defrost in progress by manually setting d13 to 0.

7.2.6 Alarms (“P” parameters)

P1: Enable buzzer

Indicates the duration of the buzzer signal in the case of an alarm:

- if P1=0, the buzzer is never started
- with a value between 1 and 14, the buzzer is automatically muted after the related value in minutes
- if P1=15, the buzzer remains active until the cause of the alarm has been removed or the RESUME button is pressed

P2: Type of remote alarm ID3

Establishes the type of response to an alarm detected by ID3. At the contact opening there may be a simple display message without any intervention on the outputs (P2=0), or may be considered as a serious alarm and thus activate the alarm relay and deenergize all outputs (P2=1).

P3: High temperature threshold

Represents the temperature threshold above which the high temperature alarm, HI T, is activated (after P5 delay). The minimum variation, depending on the unit of measure chosen with S7, is 0,5°C if S7=0 and 1°F if S7=1.

P4: Low temperature threshold

Represents the temperature threshold below which the low temperature alarm, LO T, is activated (after P5 delay). Such limit is valid even when the machine is OFF, allowing the heat actuators start up and avoiding damages in ambient in case the external temperature with disabled regulation suddenly falls too low; this function depends on parameter R14.

The minimum variation, depending on the unit of measure chosen with S7, is 0,5°C if S7=0 and 1°F if S7=1.

P5: High and low temperature alarm delay

Represents the delay in activation of the high and low temperature alarms. The delay is zeroed every time temperature rises/drops again above/below the low and high limits, i.e. between P3 and P4.

P6: Delay in general alarm on ID3

This represents the delay in the intervention of the general alarm on digital input no.3. This delay is recounted whenever the digital input opens, and the alarm signal is activated when the time P6 has elapsed, if the input is open again.

P7: Low humidity alarm threshold

This represents the humidity threshold below which the low humidity alarm LO H is activated (after the delay P5).

P8: High humidity alarm threshold

This represents the humidity threshold over which the high humidity alarm HI H is activated (after the delay P5).

P9: Low pressure alarm delay in cooling

This represents the delay in the acquisition of the low pressure alarm LO P on digital input no.2, if the unit is operating in cooling mode. Alarm always enabled; when P9=0 the alarm is immediate.

P10: Low pressure alarm delay in heating

This represents the delay in the acquisition of the low pressure alarm LO P on digital input no.2, if the unit is operating in heating mode. Setting P10=0 the alarm is disabled, and the opening of the digital input has no effect.

P11: Low pressure alarm delay in defrost

This represents the delay in the acquisition of the low pressure alarm LO P on digital input no.2, if the unit is operating in defrost mode. Setting P11=0 the alarm is disabled, and the opening of the digital input has no effect.

P12: Type of low pressure alarm reset

The low pressure alarm LO P can reset automatically, manually or a combination of both.

When P12=0 the reset is automatic, that is, after the alarm goes off, when the digital input closes again the alarm automatically disappears, including the signal on the display.

When P12=1 the reset is manual, that is, after the digital input has closed again, the Resume button needs to be pressed for 3 seconds for the display of the alarm signal to disappear.

When P12=2÷5 a number of automatic resets are performed, equal to the value of P12 (from 2 to 5) within 1 hour from the first alarm; if, still within 1 hour, another alarm occurs, it will require manual reset. This is a method used to prevent the machine from shutting down after just one alarm, allowing the possibility to restart operation. After 1 hour from the first alarm, the count is set to zero and then starts again from the following LO P alarm signal.

7.2.7 General machine configuration parameters (“H” parameters)

H1: Machine model

This parameter allows to select the type of machine to be controlled.

WARNING: before modifying parameter H1 the machine should be switched OFF, as the outputs will change function.

For a detailed description please refer to the **Application section**.

H2: Programmable output This parameter allows the function of the programmable relay output to be selected. This output is indicated by the letters OP in the functions table in the **Applications section**.

For a detailed description please refer to the **Applications section**.

H3: Enable Heating/Cooling or filter alarm digital input (ID1)

If H3=0, the Heating/Cooling digital input (ID1) on the power board is not enabled.

If H3=1, input ID1 is enabled and the Heating or Cooling operating mode set by the input itself has priority over that set on the keypad.

If H3=2 input ID1 has the function of non-serious alarm input to signal the need of changing the filter (open contact: clogged filter alarm, closed contact, no alarm). For a description of the digital inputs please refer to section **Digital inputs**.

H4: Enable remote ON/OFF digital input (ID2)

If H4=0, the ON/OFF digital input (ID2) on the power board is not enabled.

If H4=1, input ID2 is enabled; the opening of the contact (machine OFF) has priority over the operating mode set on the keypad. (the machine can operate only when allowed by both the remote and keypad).

For a description of the digital inputs please refer to section **Digital inputs**.

H5: Enable Alarm/ defrost termination digital input (ID3)

If H3=0, the digital input ID3 on the power board is not enabled.

If H3=1, input ID3 is enabled.

For a description of the digital inputs please refer to section **Digital inputs**.

H6: Keypad lock

If H6=1 the side buttons for programming the instrument are disabled. Only the front buttons and the code-protected combination of buttons remain enabled.

H7: LCD display selection

Establishes what is displayed on the field in the top right of the display.

- H7=0: value read by probe B2 (valid only if the probe is present, thus with S1=1 or S1=2)
- H7=1: value of the current set point
- H7=2: value read by probe B3 on the power board for defrost control.

H8: Set point overriding time

Establishes the duration of the temporary modification of the current set point, which may be performed using the front buttons, in time-band operation. This duration is shown in place of the clock indication and it is updated every hour.

If H8=0 the set point can not be overridden.

H9: Time format: 12-24 hours

Establishes the time display format. If H9=0, the format is 24 hours. If H9=1, the format is 12 hours with the AM or PM symbols.

H10: LCD contrast

Allows the contrast of the display to be varied.

H11: Enable button “click”

Allows the pressing of each button to be followed by the sounding of the buzzer (H11=1), or not (H11=0).

H12: Front button backlit when not acting the buttons

Allows the level of luminosity of the front buttons when the keyboard is not operated to be selected. H12=0: buttons not illuminated; H12=1: buttons 50% illuminated.

H13: Enable clock

Enables the presence of the and if this is built-in to the instrument (H13=1), or if it comes from the Carel pLAN local network (H13=2). In fact, in case there is a multi-zone application the clock management must be centralized on the pCO; the connected Aria will not have the clock option.

WARNING: turn the machine off and on again after changing this parameter.

H14: Valve logic

This sets the logic of the cycle reversing relay. H14=0 means that the relay is open in heating, and closed in cooling. H14=1 means that the relay is closed in heating, and open in cooling.

H15: Dehumidification in Unoccupied and Night-time mode

This parameter can be used to exclude the dehumidification function in the Unoccupied and Night-time modes; H15 is valid if the dehumidification function has been enabled by parameter r7.

H16: Enable set point compensation

When H16=1 the compensation of the temperature set point is enabled, and the system respects the parameters R23, R24, R25 and R26.

H17: Pump flow switch alarm delay

This is the delay referred to the acquisition of the pool water flow switch alarm on digital input no.2. Note that this alarm can only be used when H1=17.

H18: Pump operation

Three different operating modes are available for the pool water pump. H18=0, the pump is on when the water heaters are on; H18=1, the pump is always on; H18=2, the pump is always on in Comfort mode, while in Unoccupied and Night-time mode it is on when the heaters are on.

7.2.8 pLAN communication (“L” parameters)**L1: pLAN serial address**

Establishes the “Aria” address or for serial connection to a Carel pCO or pCO² controller, or for connection to a supervisor via RS485 line.

WARNING: turn the machine off and on again after changing this parameter.

L2: pLAN destination address

Establishes the address of the Carel pCO control to which the variables are sent via pLAN network. If L2=0, the sending of the variables is disabled.

L3: pLAN page

Represents the page of memory of the Carel pCO to which the variables are written. The pages contain 256 bytes each. For example, L3=181 (0xB5) indicates the pages from 0xB500 to 0xB5FF.

L4: Damper running time

Represents the time taken by the damper to move from being completely closed to completely open. For correct regulation, this parameter must be set with care, as the control calculates the position of the damper based on the activation time of the closing and opening commands. The time L4 is valid both for the damper in Stand Alone mode, that is, using power board TAZONE0000, and for the damper in Free-cooling and Free-heating.

L5: Source selection

Each of the 8 bits of this parameter has a precise meaning.

It allows the origin, local (bit=0) or from pLAN (bit=1), of a number of variables to be selected:

- bit 0: probe B1
- bit 1: probe B2
- bit 2: probe B3
- bit 3: not used
- bit 4: digital input ID1
- bit 5: digital input ID2
- bit 6: digital input ID3
- bit 7: set point category when in time band operating mode

L6: Type of protocol and presence of power board

Given that the 3 connectors on the rear of the Aria terminal (Gnd, Rx and Tx) can be used both to connect the pLAN network to a pCO or pCO², and to connect a RS485 serial line to a supervisor, L6 is used to specify what has been connected.

L6=0 no connection;

L6=1 RS485 line;

L6=2 pLAN line;

L6=3 no connection.

L6 can also be used to “inform” the Aria terminal that the power board is not connected (in this case, Aria is supplied by an external source), so as to prevent the E SR alarm from blocking the programming and being permanently visible on the display.

L6=4 no connection and no I/O board;

L6=5 RS485 line and no I/O board;

L6=6 pLAN line and no I/O board.

L7: Supervisor communication speed

Selects the communication speed for the data sent across the RS485 serial line. L7=0 1200 baud; L7=1 2400 baud; L7=2 4800 baud; L7=3 9600 baud.

8. DIMENSIONS

The Figures below provide the dimensions, in mm, of the terminal and the power board (Fig.8.2 and 8.3)




Fig. 8.1




Fig. 8.2




Fig. 8.3

9. TECHNICAL SPECIFICATIONS

The control's electrical specifications are as follows.

9.1 Terminal board

power supply	from power board
connection to power board	using a bipolar cable with cross-section from 0.5 to 1.5mm ² , depending on the length of the connection: from 0 to 50m: min. 0.5mm ² ; from 50 to 150m: min. 1mm ² *
maximum distance from power board (m)	150
connection to pLAN network	via twisted and shielded cable AWG20 or AWG22 (1 pair +shield)
analogue inputs	1 (B1) for NTC Carel regulation probe field of measurement 0°C / 50°C resolution 0.5°C / 1°F accuracy 1.5 °C / 3 °F through entire field of measurement 1 (B2) for voltage inputs -0.5 / 1 Vdc, with 20mV accuracy. Internal humidity sensor with: field of measurement 10%/90% R.H. accuracy ±6% in temperature range 0+50°C, ±3% at 25°C. Temporary variations of up to ±10% R.H. are possible in the presence of 10V/m electrical fields
PTI of materials used for insulation (V)	600
operating temperature	0T50 °C / 90% UR non condensing
storage temperature	-10T65 °C / 90% UR non condensing
operating humidity (% R.H.)	20 / 90
storage humidity (% R.H.)	0 / 90
surface temperature limits	as per operating temperature
Max. no. of terminals in the pLAN network	30
mounting	Wall
index of protection	IP30

Tab. 9.1.1

* Avoid installation near power cables, using shielded cables if possible. In such a case connect the shield to terminal G0, reference for the power supply, leaving the other end free

9.2 Relay power board for stand-alone units

power supply	24Vac +10% -15% at 50-60Hz, protected by external 1 AT fuse
minimum electrical power required (VA)	12
connection to terminal	using a bipolar cable with cross-section from 0.5 to 1.5mm ² , depending on the length of the connection: from 0 to 50m: min. 0.5mm ² ; from 50 to 150m: min. 1mm ² *
maximum distance from terminal (m)	150
analogue inputs	1 (B3) for NTC Carel probe: field of measurement -40 °C / 80 °C resolution 0.5 °C / 1 °F accuracy 1 °C / 2 °F between 0°C and 50 °C; 1.5 °C / 3 °F between -40 °C and 0 °C and between 50 °C and 80 °C
digital outputs	<ul style="list-style-type: none"> 5 or 7 depending on the relay model, 2 of which with switching contacts and the others with contacts normally open; all contacts are protected by a 250Vac varistor; relay output power: 2500VA, 10A resistive at 250Vac
digital inputs	3 optically-isolated 24Vac/Vdc inputs; the 24Vac/Vdc power supply of the inputs must be different from that of the board to allow true optical isolation
lead cross-section (mm²)	min. 0,5 - max 2,5
no. of automatic cycles (A) for each automatic action	100,000
ageing characteristic (h)	60,000
action-disconnection type for each individual circuit	1B
operating temperature	0T50 °C / 90% RH non condensing
storage temperature	-10T65 °C / 90% RH non condensing
operating humidity (% R.H.)	20 / 90
storage humidity (% R.H.)	0 / 90
surface temperature limits	as per operating temperature
mounting	in the electrical panel
index of protection	open board (taken care of by the installer)

Tab. 9.2.1

* Avoid installation near power cables, using shielded cables if possible. In such a case connect the shield to terminal G0, reference for the power supply, leaving the other end free

9.3 Triac power board for multi-zone applications

power supply	24Vac +10% -15% at 50-60Hz, protected by external 1 AT fuse
minimum electrical power required (VA)	12
connection to terminal	using a bipolar cable with section from 0,5 to 1,5mm ² depending on the length of the connection: from 0 to 50m: sec. min. 0,5mm ² ; from 50 to 150m: sec. min. 1mm ² *
maximum distance from terminal (m)	150
analogue inputs	1 for NTC Carel probe: field of measurement -40 °C / 80 °C, resolution 0.5 °C / 1 °F, accuracy 1°C/2°F between 0°C and 50°C; 1,5°C/3°F between -40°C and 0°C and between +50°C and +80°C
digital outputs	2 x 24 Vac triac outputs, 8VA max
action-disconnection type for each individual circuit	1C

Tab.9.3.1

* Avoid installation near power cables, using shielded cables if possible. In such a case connect the shield to terminal G0, reference for the power supply, leaving the other end free

digital inputs	3 optically-isolated 24Vac/Vdc inputs. The 24Vac/Vdc power supply of the inputs must be different from that of the board to allow true optical isolation
lead cross-section (mm²)	min. 0.5 - max 2.5
operating temperature	0T60 °C / 90% UR non condensing
storage temperature	-20T70 °C / 90% UR non condensing
surface temperature limits	as per operating temperature
mounting	DIN rail
index of protection	IP40

Tab. 10.3.2

9.4 Common characteristics for components indicated above

classification regarding protection against electrical shock	to be integrated into class I and/or II devices
period of electrical stress across the insulating parts	Long
degree of environmental pollution	Normal
control device	designed to be supplied to manufacturers, installers and maintenance operators
category of resistance to heat and fire	category D
protection against voltage surges	category 1
software class and structure	control device with class A software

Tab. 10.4.2

9.5 Protection against electric shock

The system made up of power board plus terminal constitutes a control device to be integrated as part of a machine.

The class of protection against electrical shock thus depends on how the control device is integrated into the machine by its manufacturer.

The power board features extra insulation between the low voltage parts and the area of connection of the digital outputs as well as primary insulation between the various digital output connections.

A Class II machine can thus be configured, using a Class II safety transformer as the power supply, to guarantee the required protection against electrical shock. **Disconnect the power supply before performing operations on the board during assembly, maintenance and replacement.**

Protection against short-circuits, due to defective wiring, must be guaranteed by the manufacturer of the machinery into which the device is integrated.

The control is made up of both plastic and metal parts.

All these parts must be disposed of according to the local standards in force on the matter of material disposal.

10. SOFTWARE UPDATING

10.1 Notes for the release 3.4 (and the following ones):

The software release 3.4, in comparison with the previous 2.0 rel., includes the following changes in the following paragraphs of the manual:

2.1, 2.4, 2.5, 2.6 = applications

4.2.6, 4.2.7, 4.2.8.4 = user interface

5.2.4, 5.2.5, 5.2.6, 5.2.7, 5.2.8, 5.2.9, 5.3.2, 5.4 = operation

5.5.1 = pLAN

5.6 = digital inputs

5.7 = supervisor

6.2 = alarms

7.1.1 = parameters

7.2 = description of the parameters

Programming with hardware key:

- With a release 2.0 programmed key, when programming 3.4 version, the parameters, which did not exist before, are not modified, but they keep their current value.
- With a release 3.4 programmed key it is not possible to copy the program in the previous Aria version 2.0.

Carel reserves the right to modify or change its products without prior notice.

CAREL

Technology & Evolution

CAREL srl

Via dell'Industria, 11 - 35020 Brugine - Padova (Italy)

Tel. (+39) 049.9716611 Fax (+39) 049.9716600

<http://www.carel.com> - e-mail: carel@carel.com

Agency:

cod. +030220306 rel. 2.0 dated 29/06/01